



west virginia department of environmental p

Division of Water and Waste Management
601 57th Street, S.E.
Charleston, WV 25304
Telephone: (304) 926-0495
Fax: (304) 926-0463

Steph



DIVISION OF ENVIRONMENTAL PROTECTION

WILLIAM & SUSIE SHEETS
RR 1 BOX 143 B
PAW PAW, WV 25434
st-14-06-490

Dear Sewage System Owner:

Please find your Sewage System Seal Registration Number from Department of Environmental Protection, Division of Water & Waste Management attached. Please keep this seal with your sewage system installation permit from your local health department. Thank you for your cooperation in this matter.

Sincerely,

Ellen R. Herndon
Environmental Resource Specialist III

PERMIT TO BE
PRINTED OR TYPED

STATE OF WEST VIRGINIA
Hampshire County HEALTH DEPARTMENT
ON-SITE SEWAGE DISPOSAL SYSTEM PERMIT

Permit No.: ST-14-06-490
Tax Map 7 Parcel # 00
County Road No.:

Owner: William SHEETS
Address: RR1 Box 143 B
Ran Pan, WV 25434

Certified Installer: SUSAN SHEETS
Address: RR1 Box 143 B
Ran Pan WV 25434

You are hereby issued a permit to: ☒ install, or ☐ modify an on-site sewage disposal system located:

at 29 N. S. delay NIT Road to
top of hill on left

Facility: HD-50 Design Flow: 3 BR Lot Size: 5 Sq. Ft./Acres Water Source: well

BASED UPON REVIEW OF THE INFORMATION OF YOUR SUBMITTED APPLICATION, DATED 6-7-6, AND THE PROPER
INSTALLATION OF THE HEREIN DESCRIBED SYSTEM, THE SYSTEM SHALL BE IN COMPLIANCE WITH APPLICABLE WEST VIRGINIA SEWA
SYSTEM RULES AND DESIGN STANDARDS.

The sewage system shall consist of a:

- ☒ Septic tank - Capacity: 1000 gallons or more, Constructed of: concrete.
- ☐ Soil disposal system with a minimum equivalency of 1200 square feet of conventional gravel trench are
Depth to the bottom of the trench or bed installation shall be: 24 inches from original ground surface.
- ☐ Gravel system: Lengths of lines: _____ feet, Width: 26 inch
- ☐ Chamber system: Number of units: _____, Length of lines: _____ unit
Manufacturer of chamber: _____
- ☐ Bed system: ☐ Gravel, ☐ Chamber; Length: _____ feet, Width: _____ feet.
- ☒ Other: Curtain Drain if needed Distribution Box
with 3x80' of 30" CHAMBERS

This permit is non-transferable and
automatically expires 12 months
after issue date.

This permit is **NULL and VOID**
when official inspection reveals
conditions different than those
stipulated on the permit or facts
are later found that would indicate
non-compliance with applicable
rules.

All systems must be inspected
and approved prior to being
covered with earth or placed into
use.

The applicant or his agent
must notify this department:
72 hours or more prior to
planned inspection time.

Sketch of system:

NOT TO SCALE

10,000
SQUARE FOOT
RESERVE AREA
REQUIRED

MUST BE
EMBEDDED in
30" 4.0 6" pipe
is under driveway
And is owner's
responsibility



Draw Arrow
Toward Nor

Distrib. Box on
concrete
slab

Issue Date

County Office / Phone Number

Additional specifications
on reverse:

Health Officer or Sanitary