

**Hampshire County Health Department****HC 71, Box 9****Augusta, WV 26704****Nursing: (304) 496-9640 Environmental: (304) 496-9641****Fax: (304) 496-9650****5/2/2007****Hampshire County Planning Commission
PO Box 883
Romney, WV 26757****Dear Sirs:**

This office has reviewed an application for Walter & Joanne Johnson to approve a Lot 5 in Crystal Valley Ranchetts Subdivision, and further referenced as Tax District Springfield, Tax Map 15, Parcel 12.7, Deed book 377, Page 591. This subdivision consists of 20.002 Acres. All lots require a percolation test and a sewage disposal area of 10,000 square feet where no development or structures other than the septic system shall be permitted. This lot is to be developed with an individual well and septic system to serve a single family dwelling.

Percolation test results are within limits as set forth by West Virginia CRS 16-1. Six foot soil observation holes indicate restrictions due to water table or shallow bedrock within the designated sewage disposal area as noted on the Health Department subdivision application.

The application dated 4/30/2007, is hereby approved by the Hampshire County Health Department. Any changes or revisions to the Health Department stamped and signed plat, or subsequent final plats approved based upon the approved plat, will make this approval null and void.

This approval is not permit for individual water systems or individual sewer systems. Applications for permits must be made separately to the Hampshire County Health Department.

Sincerely,

A handwritten signature in black ink, appearing to read "Terry Mayhew".

Terry Mayhew, RS**CC: Walter & Joanne Johnson**

(Attach additional pages if needed)