Texas Department of State Health Services Laboratory Report

Physical Address: 1100 West 49th Street | Austin, TX 78756



Mailing Address: PO Box 149347 Austin, TX 78714-9347

888-963-7111 Ext. 7318 CLIA: 45D0660644

Submitter: BLUEBONNET INSPECTIONS

PO BOX 451

LA GRANGE, TX 78945

LIMS Report #:

394935

Date / Time Received:

11/11/2009 3:30 pm

Sample Type:

KDELGUZZI

Water Source:

Ground Water (Well)

Date Collected:

Received By:

11/11/2009

County:

Bastrop

Time Collected: Collected By:

12:45 PM

Facility (D:

KEVIN ULLRICH

Smp Collect Pt Name:

Sampler Phone Num:

979-249-5665

Turbidity (NTU):

System Type: Sample Temp (°C):

Disinfect Resid (mg/L):

Submitter Designate:

Well Depth (ft):

350

Disinfect Type:

Sample Condition:

Ambient, Clear, Acceptable

Facility Name:

Sample Site:

1005 FM 2571 MAIN HOUSE

Smp Collect Pt ID;

Sample #:

ACW0902978 (451153)

Date Started:

11/13/2009 1.37FM

Source:

Water

Date Reported:

11/13/2009 11:04 pm

Additional Info:

Billing Comment:

10 - None

Specimen Note:

Result Test

Colifert Presence - Absence (SM9223)

Coliforms not found; Escherichia co'i not found.

Date/Time Analysis Started

11/12/2009 01:30:00 PM

Note.

Water of satisfactory bacteriological quality must be free from coliform organisms. For questions about

standards or treatment, call TCEQ at 512-239-4691.

The test results on this report relate only to the sample identified on this report

The test results on this report meet all NELAC requirements

Lab Contact:

Monica Kingsley (512) 458-7562

Authorized by: Tesas le Neils

Spsan U. Neill, Ph.D., M.B.A.

Director Laboratory Services Section

Z SingleSample_CM rpt 11/13/2009 Page 1 of 1 Print Date:

Texas Department of State Health Services Laboratory Report Physical Address 1100 West 49th Street Austin TX 78756

State Health Services

Mailing Address: PO Box 149347 Austin, TX 78714-9347

888-963-7111 Ext. 7318 CLIA: 45D0660644

Submitter: BLUEBONNET INSPECTIONS

PO BOX 451

LA GRANGE, TX: 78945

LIMS Report #:

394934

Date / Time Received:

11/11/2009 3:29 pm

Sample Type:

Ground Water (Well)

Received By:

KDELGUZZ:

Water Source:

Bastrop

Date Collected: Time Collected: 11/11/2009

County:

Collected By:

12.30 PM

Facility ID:

Sampler Phone Num:

979-249-5665

KEVIN ULLRICH

Smp Collect Pt Name:

System Type:

Turbidity (NTU):

Sample Temp (°C):

Disinfect Resid (mg/L):

Submitter Designate:

Well Depth (ft):

250

Disinfect Type:

Sample Condition:

Ambient, Clear, Acceptable

Facility Name:

Sample Site:

1005 FM 2571 RV PAD

Smp Collect Pt ID:

Sample #:

ACVV0902977 (451152)

Date Started:

11/13/2009 1:37PM

Source:

Water

Date Reported:

11/13/2009 10:59 pm

Additional Info:

Billing Comment:

10 - None

Specimen Note:

Result Test

Colifert Presence - Absence (SM9223)

Coliforms not found: Escherichia coli not found

Date/Time Analysis Started

11/12/2009 01:30:00 PM

`.ote

Water of satisfactory bacteriological quality must be free from coliform organisms. For questions about standards or treatment, call TCEQ at 512-239-4691

The test results on this report relate only to the sample identified on this report The test results on this report meet all NELAC requirements

Lab Contact:

Menica Kingsley (512) 458-7562

Authorized by:

Susan U. Neill, Ph.D., M.B.A

Director, Laboratory Services Section Z. SingleSample CM rpt

Page 1 of 1

Print Date: 11/13/2009