



PERMIT TO CONSTRUCT - CERTIFICATE OF FINAL APPROVAL Onsite Sewage Treatment and Disposal System

Work Shop (Private)

Permit No.: 29-12824 Type Facility: (Residential) TMS#: 0037-00-003.05

3385 Mockingbird Lane

Name: Sammy R. Mullis, Sr. Address: Lancaster, S.C. 29720 Sys. Category: 360/100

~~Subdivision~~ Tabernacle Street: Mockingbird Lane Section/Lot: Type Water Supply: Private Well

SYSTEM SPECIFICATIONS

Max. Est. Daily Flow: 120 GPD
Loading Rate: .4
Tank Size(s): 1,000 GALLON
(890 GALLON MINIMUM)
Trenches: Length: 100'
Width: 3'
Max. Bottom Depth: 4'
Aggregate Depth: 14'
Min. Pump Capacity: gpm
at ft. of Head


SPECIAL INSTRUCTIONS/CONDITIONS

~~DRAWING NOT TO SCALE~~

~~NO DRIVING/PARKING OR
UTILITIES IN OVER THE
ABSORPTION AREA.~~

PERMIT TO CONSTRUCT

(NTS)



EXISTING
HOUSE

WELL

ACTUAL INSTALLATION

Installer: JAMES BLACKMON

Tank(s) Mfg.: J&S

Aggregate Type: STONE

Well Installed: ☒ Yes ☐ No

Nearest Actual Distance to:

Well: 100' ++

Building: 14'

Property Line: 10' ++

Stream/Impoundment:

Line No. Elevation Readings

Stubout:

S/T Inlet:


S/T Outlet: 17' 2"

19' 2" 19' 2" 19' 2 1/4"

MOCKINGBIRD LANE TO CAMP CREEK RD →
ANY CHANGES TO SYSTEM MUST BE AUTHORIZED BY THE HEALTH DEPARTMENT PRIOR TO INSTALLATION.

CERTIFICATE OF FINAL APPROVAL

(NTS)



THIS CERTIFICATE OF FINAL APPROVAL IN NO WAY GUARANTEES THE LIFE OF THE SYSTEM OR THAT IT WILL FUNCTION PROPERLY UNDER ANY OR ALL CONDITIONS.

Issued By: [Signature] Date: 5-14-98 Approved By: [Signature] Date: 5-26-98