

WEST VIRGINIA
SEPTIC TANK INSPECTION FORM

Hampshire County Health Department Installation Permit No. ST-14-89-246
Name of Owner Richard D. Shum, Jr.
Address 1601 Quince Rd. P.O. Box 14, Mount of Hope, W.Va. 26007
Property Address West Chapman Rd. - Oakton Meadows Apts.

DESCRIPTION & NUMBER OF UNITS SERVED

Type Facility Served Grinding Colonic No. Water Closets -
Lot Size 7.9446 ^{acres} sq. ft. Area suitable for sewage disposal installation - sq. ft.
Source of Water Supply well No. Lavatories -
No. Bedrooms 3 No. Showers or Tubs - No. Baths -
No. Garbage Grinders - No. Automatic Washers -

SEPTIC TANK

Material concrete Length x Width x Depth = cubic feet
Liquid Depth ft. Liquid Capacity 1,000 gal.
Distance to: Dwelling 110' Water Supply 300' Nearest Property Line 300'

SOIL ABSORPTION SYSTEM

Type Drain Line Material 9227 PVC Trench Width 36 Inches
Trench Depth 26-30 Inches Total Absorption area in Trench Bottom 820 sq. ft.
Diameter of Drain Line 4 Inches Type Filter Media granul. 30 mesh
No. of Drain Lines 4 Depth Filter Media Under Drain Line 6 to 8 Inches
Length of Each Line 25, 50, 50, 25 ft. Depth Filter Media Over Drain Line 4 in.
Distance of Disposal Field to: (a) Dwelling 110'
(b) Water Supply well (c) Nearest Property Line 300'

An inspection of the septic tank system described herein disclosed that said system (MEETS, DOES NOT MEET) the minimum standards established by the West Virginia State Department of Health.

Date 3-20-89

[Signature]
Sanitarian

SKETCH OF SYSTEM TO BE DRAWN ON BACK

Note: Copy of this inspection report must be given to owner and the original filed in the Health Department files. PERMANENT RECORD - DO NOT DESTROY.

Hampshire Co. Health Department - 304-1916-9040
Barn - 10 am

WEST VIRGINIA
SEPTIC TANK SPECIFICATION FORM

HAMPSHIRE COUNTY HEALTH DEPARTMENT

INSTALLATION PERMIT NO. St 14-89-246

NAME OF OWNER Richard L. Green Jr.

ADDRESS 1401 Wise Rd. PO Box 14 Point of Rock's Md. 21777

PROPERTY ADDRESS Out Willow Rd. Out Meadows Dr

DESCRIPTION & NUMBER OF UNITS SERVED

TYPE FACILITY SERVED Hunting Cabin LOT SIZE 7.9146 ACRES/SQ. FT.

SOURCE OF WATER SUPPLY well NO. BEDROOMS 3

NO. GARBAGE GRINDERS none NO. AUTOMATIC WASHERS none

SEPTIC TANK

MATERIAL Concrete Tank LIQUID CAPACITY 1,000 GALLONS

DISTANCE TO: DWELLING 110 ft. WATER SUPPLY 300 ft. NEAREST PROPERTY LINE 300 ft.

SOIL ABSORPTION SYSTEM

TYPE DRAIN LINE MATERIAL 2227 PVC pipe DIAMETER OF DRAIN LINE 4" INCHES

TRENCH WIDTH 36" INCHES TRENCH DEPTH 26"-30" INCHES

NO. OF DRAIN LINES 4 LENGTH OF EACH LINE 75', 50', 50', 75', FT.

TOTAL ABSORPTION AREA IN TRENCH BOTTOM 820 SQ. FT.

TYPE FILTER MEDIA gravel TONAGE 30 Tons

DEPTH FILTER MEDIA UNDER DRAIN LINE 6 to 8 INCHES

DEPTH FILTER MEDIA OVER DRAIN LINE 4 INCHES

DISTANCE OF DISPOSAL FIELD TO: (A) DWELLING 110 ft.

(B) WATER SUPPLY well (C) NEAREST PROPERTY LINE 300 ft.

DATE 3-15-89 Billy Hunt
INSTALLER (SIGNATURE)

54-87-0270
CERTIFICATION NUMBER

SKETCH OF SYSTEM TO BE DRAWN ON BACK
(PLEASE NOTE TRANSIT READINGS)

Amber: Andy Holmes 304-947-5112

