

SUBDIVISION
Approved Lots Subject to Noted Modifications

Lot #	Lot Size Acre	Avg. Perc (Min.)	6' Excavation Observed	Reserve Area Location	Drainfield Design			Comments
					Depth	Sq. Ft. of Trench Area	Trench Separation	
38	20.18	7.4	Water at 4 feet	Platted	18"	300 sq. ft. per bedroom	standard	Class II - Low Pressure Dosing System
39	23.45	19.0	Good	Platted	18" to 24"	"	"	None
40	25.42	10.0	Good	Platted	18" to 24"	"	"	None
41	20.08	7.0	Water	Platted	18"	"	"	Class II - Low Pressure Dosing System
42	20.11	7.0	Good	Platted	18" to 24"	"	"	None
43	20.11	8.3	Good	Platted	18" to 24"	"	"	None
44	20.35	8.9	Good	Platted	18" to 24"	"	"	None
45	20.11	7.8	Water at 3 1/2 feet	Platted	18" to 24"	"	"	Curtain drain above field
46	20.21	13.6	Good	Platted	18" to 24"	"	"	None