

Attention Owner:
Confidentiality Privilege Notice
on reverse side of owner's copy.

Texas Department of Licensing and Regulation
Water Well Driller/Pump Installer Section
P.O. Box 12157 Austin, Texas 78711 (512)463-7880 FAX (512)463-8616
Toll free (800)803-9202
Email address: water.well@license.state.tx.us Web address: www.license.state.tx.us

This form must be completed
and filed with the department
and owner within 60 days
upon completion of the well.

WELL REPORT

A. WELL IDENTIFICATION AND LOCATION DATA

1) OWNER

Name: Royce Roberts Address: 5025 Barnett Shale Rd City: Athens State: GA Zip: 30605

2) WELL LOCATION

County: Kerr Physical Address: 8971 US Hwy 290 City: Harpur State: TX Zip: 78631

3) Type of Work

☒ New Well ☐ Reconditioning
☐ Replacement ☐ Deepening

Lat. 30° 17.01' N Long. 99° 23.20' W Grid # 56-45-9
4) Proposed Use (check) ☒ Monitor ☐ Environmental Soil Boring ☐ Domestic
☐ Industrial ☐ Irrigation ☐ Injection ☐ Public Supply ☐ De-watering ☐ Testwell
☐ Rig Supply ☐ Stock or Livestock If Public Supply, were plans approved? ☐ Yes ☐ No

6) Drilling Date

Started 8.13.05
Completed 8.14.05

Diameter of Hole

Dia. (in)	From (ft)	To (ft)
	Surf	
7 7/8	0	25
6 1/4	25	185

7) Drilling Method (check)

☐ Driven ☐ Air Rotary ☐ Mud Rotary
☐ Bored ☒ Air Hammer ☐ Cable Tool
☐ Jetted ☐ Hollow Stem Auger
☐ Reverse Circulation
☐ Other

From (ft)	To (ft)	Description and color of formation material
0	25	top soil
25	85	soft calciche w/ limestone
85	100	hard limestone
100	185	limestone - cave lost return
		clay

8) Borehole Completion ☒ Open Hole ☐ Straight Wall
☐ Under-reamed ☐ Gravel Packed ☐ Other
Gravel packed interval from: ft. to: ft. to: ft. to:

Casing, Blank Pipe, and Well Screen Data					
Dia. (in.)	New Or Used	Steel, Plastic, etc. Perf., Slotted, etc Screen Mfg. if commercial	Setting (ft)		Gage Casing Screen
			From	To	
6 5/8	new	steel	+1	-2	188
4 1/2	new	plastic	+2	125	SDP21
4 1/2	new	plastic perf.	125	185	SDP21

(Use reverse side of Well Owner's copy, if necessary)

13) Plugged

☐ Well plugged within 48 hours
Casing left in well: Cement/Bentonite placed in well:
From (ft) To (ft) From (ft) To (ft) Material used & # Sacks

9) Annular Seal Data: i.e. (from 0 ft to 100 ft - sacks & material 12 cement)
from 0 ft. to 25 ft. #sacks & material 5 cement
from 25 ft. to ft. #sacks & material
from ft. to ft. #sacks & material
Method Used gravity Performed By Pickens Drilling
Distance to septic field or other concentrated contamination N/A
Distance to Property Line N/A ft Method
Verified: estimated

14) Type Pump

☐ Turbine ☐ Jet ☐ Submersible ☐ Cylinder
☐ Other
Depth to pump bowls, cylinder, jet etc., ft.

10) Surface Completion (if steel cased, leave blank)
☐ Surface Slab Installed ☐ Surface Sleeve Installed
☐ Pitless Adapter Used ☐ Alternative Procedure Used

15) Water Test

Type test ☒ Pump ☐ Bailer ☐ Jetted ☐ Estimated
Yield: 8 gpm with 0 ft. drawdown after 1 hrs.

11) Water Level
Static level 90 ft. Date: 8.14.05
Artesian Flow gpm

12) Packers:

Type	Depth	Type	Depth
<u>Rubber</u>	<u>25</u>		

16) Water Quality

Type of water edwards Depth of Strata: 90 Was a chemical analysis made? ☐ Yes ☒ No
Did you knowingly penetrate a strata which contains undesirable constituents? ☐ Yes ☒ No If Yes, Continue:
Check Ones: ☐ Naturally poor-quality groundwater - type ☐ Hydrocarbons (i.e. gas, oil, etc.)
☐ Hazardous material/waste contamination encountered ☐ Other (describe)
☐ I certify that while drilling, deepening, or otherwise altering the above described well, undesirable water or constituents was encountered and the landowner was informed that such well must be completed or plugged in such a manner as to avoid injury or pollution.

Company & Individual's Name: (type or print) Will Pickens Drilling Lic. No.: 5499/LC/MW
Address: 8790. US Hwy 290 City: Harpur State: TX Zip: 78631
Signature: Will Pickens Date: 8.10.04 Signature: _____
Licensed Driller/Pump Installer _____ Date: _____ Signature: _____
TDLR FORM 001WWD / 9-03 TDLR (Original) Landowner (copy) Driller/Pump Installer (copy)

Tom Pickens Well Svc.
8790 US Hwy 290
Harper, TX 78631

FAX (830) 864-4477

Order No.: 0601256

Dear :

There were no problems with the analyses of the accompanying samples and all data for the associated Quality Control checks met EPA or laboratory specifications.

Sincerely,

1. 1. 1.

[illegible][illegible]



Kerr County Floodplain Administration

Leonard Odom, Jr., CFM
Floodplain Administrator

4010 San Antonio Hwy
Kerrville, Texas 78028

Telephone: 830-257-2993

FAX: 830-896-8481

Email: kcroads@kfc.com

Truby Hardin
Assistant Administrator

August 17, 2006

Royce & Karen Roberts
211 Oak View
Kerrville, TX 78028

RE: Floodplain Determination # F06-017


Dear Mr. & Mrs. Roberts,

Enclosed is a copy of the completed Floodplain Determination #F06-017, showing the location of your proposed home to be in Zone X of Firm 48265C075E, July 19, 2000, with the elevation being 2.3' above the Base Flood Elevation (BFE). The proposed Finished Floor will be 5.48' above the BFE.

This completes the requirements of Kerr County Flood Damage Prevention Order # 26463, however, in the future should you do work within the area of your property located in Zone A you will need to contact this office again to assure you are in compliance with the Order.

If you have any questions or need more information, please call.

Sincerely,


Leonard Odom, Jr.
Administrator

USAA # - 3369410