

Texas Department of License and Regulation
WELL REPORT

TDLR FORM 001WWD

This form must be completed and filed with the department and owner within 60 days upon completion of the well.

WELL IDENTIFICATION AND LOCATION DATA

1) OWNER GREGORY & JULIE EFFERSON **Address:** 1522 RIVERWOOD DR.
Owner ID #: CS7969 San Angelo TX 76905

2) WELL LOCATION

County: TOM GREEN 200 Feet from NORTH Property Line.
 miles in direction from 300 Feet from West Property Line.

Legal Description **Section No. :** 158 **Abstract:** 345 **Survey:** ADOLPH ZOBEL **Block No.:** C-3

3) Type of Work: New Well **4) Proposed Use:** Domestic **5) Drilling Method:** Air Rotary

6) Drilling Date:

Completed:

04/20/1995

Diameter of Hole

Dia. (in.)

From (ft.)

To (ft.)

Surface

8

0

130

6.5

60

130

7) Borehole Completion:

Straight Wall

Gravel Packed: No

If Gravel Packed, give interval...

from ft. to ft.

Latitude:

31 26 57 N

Longitude:

100 21 26 W

From (ft) **To (ft)** **Description and color of formation material**

0	2	TOPSOIL
2	18	caliche
18	45	conglomerant
45	60	yellow lime & clay
60	97	blue lime & clay
97	110	Blue lime & shale
110	130	Red shale
60	102	water

8) Casing, Blank Pipe, and Well Screen Data:

	Dia (in)	Casing Type	Depth (ft.)	
			From	To
Surface	<u>8</u>	<u>Steel</u>	<u>0</u>	<u>130</u>
Well	<u>5.625</u>	<u>Plastic</u>		
Screen				

9) Cementing Data:

Cement: Fm 0 ft. To 15 ft. **Sacks Used:** 5

Method Used:

Poured From Top

Cemented By:

Hoelscher Pump & Supply

10) Surface Completion:

Steel Sleeve--Cement

Length (ft): **Width (ft):**

Height (in.):

Completed By:

Hoelscher Pump

13) ☐ **Well plugged within 48 hours:** **Plugged by:**

Casing left in well: **Cement/Bentonite placed in well:** **Sacks Used:**

From (ft)	To (ft)	From (ft)	To (ft)	Sacks Used:

11) Water Level:

Static Water Level: 40 ft.

Date: 04/20/1995

14) Pump Type: Submersible **HP:** 1

Depth to Bowls: ft **Discharge Size:** in.

12) Packers: Yes

Packer Type: Rubber **Depth:** 15 ft.

15) Well Tests: **Type Test:** Estimated

Yield: 30 GPM

16) Water Quality: **Quality Checked?** No

Drilling penetrated strata containing undesirable constituents? No

Water Type: **Depth of Strata:** ft.

Driller Name: Hoelscher Pump & Supply **Driller License:** 02409WI

Address: 11385 Fm Hwy 765 San Angelo TX 76904

Pump Installer Name: **Installer License:**

Address:

TNRCC Grid #: 43-38-4 **State Well No.:** **TOPO Map Number:** 43-38-4 **LK Well #:** G-200

Latitude: 31-26-57 N **Longitude:** 100-21-26 W **Coordinate Source:** GPS **Lipan-Kickapoo Log #** DL 0407