

AS - Apison 75 mps to 30" 2-20%

LE - Leadvale 75 mps to 30" with interceptor drain at 42" 2-10%

LT/Sg - Litz + Sequoia soils >75 mps 2-25% can perk

WSA - wet soil Area cannot perk

DP - Dirt pile/Burd pile - can be removed

High Intensity SOIL MAP BY
EAST TN SOIL CONSULTANTS

Eddie McCracken 2-27-06
SOIL CONSULTANT DATE

ANY CUTTING, FILLING OR
COMPACTION WILL VOID
THIS SOIL MAP

APPROVAL IS HEREBY GRANTED FOR LOTS 1-16 DEFINED AS
GATLIN PLACE, BRADLEY COUNTY TENNESSEE, AS BEING SUITABLE
FOR SUBSURFACE SEWAGE DISPOSAL (SSD) WITH THE LISTED RESTRICTIONS.

1. PRIOR TO ANY CONSTRUCTION OF A STRUCTURE, MOBILE OR PERMANENT THE
PLANS FOR THE EXACT HOUSE/STRUCTURE MUST BE APPROVED AND A SSD PERMIT
ISSUED BY THE TENNESSEE DIVISION OF GROUND WATER PROTECTION. WATER
TAPS, WATER LINES, UNDERGROUND UTILITIES AND DRIVEWAYS SHOULD BE LOCATED
AT THE SIDE PROPERTY LINES UNLESS OTHERWISE NOTED. ANY CUTTING, FILLING
OR ALTERATIONS OF THE SOIL CONDITIONS MAY VOID THIS APPROVAL.



www.tnlandandhome.com