

Chetley - Gravel
11/1/2002

WEST EAST
 SOUTH
 May 20

DESTROY (Destroy Procedures and Materials Under "SELODING 100")

PLANNED USES ()
 WATER SUPPLY
☒ Domestic ☐ Public
☐ Irrigation ☐ Industrial

MONITORING ☐
 TEST WELL ☐
 CATHODIC PROTECTION ☐
 HEAT EXCHANGE ☐
 DIRECT PUSH ☐
 INJECTION ☐
 VAPOR EXTRACTION ☐
 SPARGING ☐
 REMEDIATION ☐
 OTHER (SPECIFY) ☐

WATER LEVEL & YIELD OF COMPLETED WELL
 DEPTH TO FIRST WATER 80 (FL) BELOW SURFACE
 DEPTH OF STATIC WATER LEVEL 48 (FL) & DATE MEASURED 9-17-02
 ESTIMATED YIELD 10 (GPM) & TEST TYPE AIR LIFT
 TEST LENGTH 1 (FL) TOTAL DRAWDOWN (FL)
 * May not be representative of a well's long-term yield.

TOTAL DEPTH OF BORING 200 (Feet)
 TOTAL DEPTH OF COMPLETED WELL 200 (Feet)

DEPTH		ROD HOLE DIA. (Inches)	CASING (8)					DEPTH		ANNULAR MATERIAL							
FL	TO		BLANK	SCREEN	COR- DUCTOR	FILL PIPE	MATERIAL / GRADE	INTERNAL DIAMETER (Inches)	GAUGE OR WALL THICKNESS	SLOT SIZE IF ANY (Inches)	FL	TO	FL	CE- MENT (<u> </u>)	BEN- TONE (<u> </u>)	FILL (<u> </u>)	FILTER PACK (TYPE/SIZE)
0	24	10						10			0	24			X		
0	24	"					PVC	6"	F-480								
24	200	6						6									
							PVC	4	F-480								
			P	P	P		PVC	4	F-480	6 X 7/8							
							PVC	4	F-480								
							PVC	4	F-480								

No 4781

Beymer & Son

Wells, Pumps, Septic Systems Complete Site Development

Mailing Address:
 P.O. Box 716
 Browns Valley
 California
 95918



LIC. NO. 528482

Browns Valley 530-741-1971
 Grass Valley 530-274-8883
 Marysville 530-634-0183
 Oroville 530-532-6383
 Sacramento 916-991-6371



STEVE & NAEDE YACARIELI

8060 ARVIN PLACE

HEDMIS, CA 95626

916-652-0836

- ☐ Invoice
☐ Proposal
☐ Contract

DATE	DESCRIPTION	CHARGES	BALANCE
9-12-02	6" WELL		
	9750 DEER HOLLOW TRAIL		
200'	6" Drilling		
24'	6" Casing		
20'	Sanitary Seal		

938 14TH STREET
MARYSVILLE, CA 95901
(530) 741-6251

P 2/11
FEE: 240 PAID: 13259

RECEIPT NO.

2005 570 174

ASSESSOR'S PARCEL NO.

APPLICATION FOR PERMIT TO CONSTRUCT, REPAIR, INACTIVATE, OR DESTROY A WELL 005 - 600 012

JOB LOCATION 9750 DEER HOLLOW TRAIL NEAREST CROSS STREET TURNER AVENUE
OWNER OF RECORD STEVE & ANNE HARRIS PHONE _____
MAILING ADDRESS 6060 QUINN PLACE LEMMING CA. 95650
DRILLING CONTRACTOR BERNARD SAN LUIS RENT LICENSE # 538464
MAILING ADDRESS PO. Box 716 DENNIS WALKER PHONE 531-0185

PERMITTED ACTIVITY

☒ CONSTRUCT NEW WELL ☐ INSTALL NEW PUMP ☐ OTHER (STATE) _____
☐ DEEPEN WELL ☐ REPAIR PUMP ☐ TEST HOLE W/DESTRUCTION
☐ REPAIR WELL ☐ DESTROY WELL ☐ INACTIVATE WELL

COMMENTS: _____

INTENDED USE

TYPE OF WELL

CONSTRUCTION SPECIFICATIONS

☒ DOMESTIC/PRIVATE ☐ CABLE TOOL ANNUAL SPACE: DIAM. 10" DEPTH OF SEAL 30'
☐ PUBLIC WATER SUPPLY (SEE 00 PAR 10, ENV.) ☒ ROTARY MATERIAL USED: DEPT GRAVEL PACK ☒ YES ☐ NO
☐ IRRIGATION ☐ OTHER (STATE) CASING: DIAM. 6" DEPTH _____
☐ INDUSTRIAL IF STEEL, GAUGE _____ OR THICKNESS _____
☐ MONITOR IF PLASTIC, TYPE F-480 (MUST MEET ASTM F-480)
☐ OTHER (STATE) IF CONDUCTOR, DIAM. _____ DEPTH _____

WELL LOCATED WITHIN AN EXISTING PUBLIC WATER SYSTEM BOUNDARY: ☐ YES ☒ NO NAME: _____

COMMENTS: _____

WELL IDENTIFICATION

DATE

BY

YUBA COUNTY ENVIRONMENTAL HEALTH DEPARTMENT
WATER WELL FIELD RESPONSE FORM

Permit No: 5156 Date: _____
Owner/Dev: Steve, Arlene Yarnally APN: 005-600-012
Site Location: 9750 Deer Hollow Trail, Browes Valley
Type of Work Inspected: Const ☒ Dest _____ Other _____
Driller: Bygner / Son Well Drilling Method: air rotary
Total depth: 200 feet Diameter of Bore 10"
Prod. casing depth: 24 feet Conductor casing depth _____ feet
Type: PVC Type: _____
Diameter 6" Diameter: _____
Gauge: _____ Gauge: _____
Perforation depth: _____ Well Screen: _____
Perforation size: _____ (type, size)
Gravel pack: From 0 to _____ Gravel size _____ inches.
Type of rock strata: 0 to 18 Red Brown Clay
125-137 Broken 18 to 80 Dyr.ite
quartz 80 to 89 Broken Dyr.ite/Quartz
137-200 Black and 89 to 125 Dyr.ite
Blue Dyr.ite
Vegetation: _____
Potential Sources of Contamination: 0 Distance _____ ft
Surrounding Land Use: proposed residential
Annular Seal Depth: 24 feet Grout: Bentonite Hydro