

**The Department of Ecology does NOT Warranty the Data and/or the Information on this Well Report.**

Start Card No. W091760

UNIQUE WELL ID. # 12091760

STATE OF WASHINGTON

Water Right Permit No.

(1) OWNER: Name FRANK STADLER Address 5813 N. NORTHWOOD SPOKANE, WA

(2) LOCATION OF WELL: County Soo LOT 13 NE 1/4 SW 1/4 Sec 6 T. 24 N., R. 4E WM.

(2a) STREET ADDRESS OF WELL (or nearest address) Linker Rd

(3) PROPOSED USE: ☒ Domestic ☐ Industrial ☐ Municipal ☐  
☐ Irrigation ☐ Test Well ☐ Other ☐  
☐ DeWater

(4) TYPE OF WORK: Owner's number of well (if more than one) \_\_\_\_\_

Abandoned <input type="checkbox"/>	New well <input checked="" type="checkbox"/>	Method: Dug <input type="checkbox"/>	Bored <input type="checkbox"/>
Deepened <input type="checkbox"/>		Cable <input type="checkbox"/>	Driven <input type="checkbox"/>
Reconditioned <input type="checkbox"/>		Rotary <input checked="" type="checkbox"/>	Jetted <input type="checkbox"/>

(5) **DIMENSIONS:** Diameter of well 6 inches.  
Drilled 700 feet. Depth of completed well 700 ft.

(6) CONSTRUCTION DETAILS:

Casing installed: 6 • Diam. from +1 ft. to 79 ft.  
Welded OK • Diam. from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.  
Liner installed ☐ • Diam. from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.  
Threaded ☐ • Diam. from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.

Perforations: Yes ☐ No ☒   
 Type of perforator used \_\_\_\_\_   
 SIZE of perforations \_\_\_\_\_ in. by \_\_\_\_\_ in.   
 \_\_\_\_\_ perforations from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.   
 \_\_\_\_\_ perforations from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.   
 \_\_\_\_\_ perforations from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.

Screens: Yes ☐ No ☒

Manufacturer's Name \_\_\_\_\_

Type \_\_\_\_\_ Model No. \_\_\_\_\_

Diam. \_\_\_\_\_ Slot size \_\_\_\_\_ from \_\_\_\_\_ fl. to \_\_\_\_\_ fl.

Diam. \_\_\_\_\_ Slot size \_\_\_\_\_ from \_\_\_\_\_ fl. to \_\_\_\_\_ fl.

Gravel packed: Yes ☐ No ☒ Size of gravel \_\_\_\_\_  
Gravel placed from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.

Surface seal: Yes ☒ No ☐ To what depth? 79 ft.  
Material used in seal BENTONITE  
Did any strata contain unusable water? Yes ☐ No ☒  
Type of water: \_\_\_\_\_ Depth of strata \_\_\_\_\_  
Method of sealing strata off \_\_\_\_\_

(7) PUMP: Manufacturer's Name \_\_\_\_\_  
Type: \_\_\_\_\_ H.P.

(8) **WATER LEVELS:** Land-surface elevation \_\_\_\_\_ ft.  
above mean sea level \_\_\_\_\_ ft.  
Static level 30 \_\_\_\_\_ ft. below top of well Date \_\_\_\_\_  
Artesian pressure \_\_\_\_\_ lbs. per square inch Date \_\_\_\_\_  
Artesian water is controlled by \_\_\_\_\_ (Cap. valve, etc.)

(9) **WELL TESTS:** Drawdown is amount water level is lowered below static level  
 Was a pump test made? Yes ☐ No ☐ If yes, by whom? \_\_\_\_\_  
 Yield: \_\_\_\_\_ gal./min. with \_\_\_\_\_ ft. drawdown after \_\_\_\_\_ hrs.

APPROX. 2 GM BY AIR TEST

Recovery data (time taken as zero when pump turned off) (water level measured from well top to water level)					
Time	Water Level	Time	Water Level	Time	Water Level

[illegible]

Date of test \_\_\_\_\_

Bailer test \_\_\_\_\_ gal./min. with \_\_\_\_\_ ft. drawdown after \_\_\_\_\_ hrs.

Airstest \_\_\_\_\_ gal./min. with stem set at \_\_\_\_\_ ft. for \_\_\_\_\_ hrs

Artesian flow \_\_\_\_\_ g.p.m. Date \_\_\_\_\_

Temperature of water \_\_\_\_\_ Was a chemical analysis made? Yes ☐ No ☐

(10) WELL LOG or ABANDONMENT PROCEDURE DESCRIPTION

Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of information.

MATERIAL	FROM	TO
UPPSOLIC	0	1
BRN CLAY - FINE	1	12
BLK CLAY - MED.	12	30
DECOMP. GRANITE - SOFT	30	55
DECOMP GRANITE - MED, FRACTS	55	200
1/2-1 GPM		
GRANITE - HARD, FRACTS, &	200	700
DECOMP. AREAS 2 GPM		

Work Started 8/7, 1941. Completed 8/14, 1941.

**WELL CONSTRUCTOR CERTIFICATION:**

I constructed and/or accept responsibility for construction of this well, and its compliance with all Washington well construction standards. Materials used and the information reported above are true to my best knowledge and belief.

NAME CARPENTER, KILLING, CO.  
(PERSON, FIRM, OR CORPORATION) (TYPE OR PRINT)

Address 8918 N. FORKER PL. SPOKANE, WA

(Signed) B. CARPENTER License No. 1278

Contractor's  
Registration  
No. CAAE00897P2 Date 8/5 1997

(USE ADDITIONAL SHEETS IF NECESSARY)

**Ecology is an Equal Opportunity and Affirmative Action employer. For special accommodation needs, contact the Water Resources Program at (206) 407-6600. The TDD number is (206) 407-6006.**