NOTICE TO WATER WELL CONTRACTOR KLAM
The original and first copy of this report are to be

filed with the

1032 WATER WELL REPORT GEIVED STATE OF OREGON AUG2 8 1974 State Well No. 345 8E-Z3ccl

STATE ENGINEER, SALEM, OREGON 97310 within 30 days from the date of well completion.

(Please type or print) STATE ENGINEER State Permit No. (Do not write above this lineALEM, OREGON

(1) OWNER:	(10) LOCATION OF WELL:			
Name Mr & Mrs Jack Gaston	County Klamath Driller's well nu		773	
Address Akz 3142 Summers Lane Klamath Falls, Oregon 97601	SW 14 SE 14 Section 23 T. 34		E	W.M.
	Bearing and distance from section or subdivision	n corner		SE
(2) TYPE OF WORK (check):	2000 feet west and 500 feet N	OT CEL O	1 0116	 -
New Well Deepening Reconditioning Abandon	corner of S23 T 34 R8 E			
If abandonment, describe material and procedure in Item 12.	(11) WATER LEVEL: Completed we	ell.		
(3) TYPE OF WELL: (4) PROPOSED USE (check):	Depth at which water was first found	25		ft.
Rotary Driven Domestic L Industrial Municipal	Static level 15 ft. below land s	arface. Da	ate 8	<u>/14/7</u> 4
Cable	Artesian pressure lbs. per square	e inch. D	ate 💳	
CASING INSTALLED: Threaded \(\text{Welded X} \) 6 5/8' Diam. from \(\text{O} \) ft. to \(20 \) ft. Gage \(\text{250} \) 7 Diam. from \(\text{ft. to } \) ft. to \(\text{Gage } \) PERFORATIONS: Perforated? \(\text{Yes} \) Yes \(\text{No} \)	(12) WELL LOG: Depth drilled 170 ft. Depth of completed well 170 ft. Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.			
Type of perforator used	MATERIAL	From	то	swL
Size of perforations in. by in.		0	3	
perforations fromft. toft.	Top soil Sand & gravel	3	4	
perforations fromft. toft.	Brown clay	4	25	
perforations from	Blue clay	25	55	
periorations from	Green clay or chalk	55	120	
(7) SCREENS: Well screen installed? Yes No	black sand	120	122	15_
Manufacturer's Name	green Rink chalk or clay	122	130	
Type Model No.	/Black chalk or clay	130	135	
Diam. Slot size Set from ft. to ft. to	Green_clay	135	155	
Diam. Slot size Set from ft. to ft.	Grey clay	155	160	
(8) WELL TESTS: Drawdown is amount water level is	Black & red sand	160	162	15
lowered below static level	<u> </u>	162	170	
Was a pump test made? ☐ Yes ₹ No If yes, by whom?	1 12			
Yield: gal./min. with ft. drawdown after hrs.				_
Air lifted from 150 feet "				
" 45 G.P.M." for 2 hrs. " "				
Bailer test gal./min. with ft. drawdown after hrs.				
Artesian flow g.p.m.		<u> </u>		
perature of water 50 Depth artesian flow encountered	Work started Aug 14 19 74 Complete	ed Aug j	14	19 74
(9) CONSTRUCTION:	Date well drilling machine moved off of well	Aug 15		19 74
Comont	Drilling Machine Operator's Certification:			
Well sealed from land surface to 20 ft. Diameter of well bore to bottom of seal 10 in.	This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.			
Diameter of well bore below seal 6 in.	[Signed] Color Allow Date * 15, 1974.			
Number of sacks of cement used in well seal 5 sacks	Drilling Machine Operator's License No. 201			
Number of sacks of bentonite used in well seal sacks	Diffing Machine Operators 2 months			
Brand name of bentonite	Water Well Contractor's Certification:			
Number of pounds of bentonite per 100 gallons	This well was drilled under my jurisdiction and this report is			
of waterlbs./100 gals. Was a drive shoe used? Yes No PlugsSize: locationft.	true to the best of my knowledge and belief.			
Did any strata contain unusable water? Yes No	Name Wilson Drilling Contractor Inc. (Person, firm or corporation) (Type or print)			
	Address P.O. Box 136, Merrill, Oregon 97633			
Type of water? depth of strata	9 1 - (P 9) - ()			
Method of sealing strata off	[Signed] (Water Well Cont	ractor)	لسعهي	
Was well gravel packed? ☐ Yes K No Size of gravel:		•		10 -
Gravel placed fromft. toft.	Contractor's License No. 169 Date	8/15		, 1874