

**Hampshire County Health Department
On-Site Sewage Disposal System
Inspection Form**

Permit # **ST-14-09-38**

Name of Owner: Andrew J. Walter Installer: Eugene Rinker
Address: 115 Riverbreeze Place, Arnold, MD 21012
Property Location: Bluffs on the Potomac Lot 137 Lot Size: 25.53 Acres
Type of Facility: Residence Facility is: ☒ New ☐ Existing
Design Loading in gpd/# Bedrooms: 1 Source of Water: Well

SEWAGE TANK COMPONENT

Capacity in Gallons: **1000** Material: precast concrete Manufacturer: _____
Pump Chamber _____ gal
Distances (in feet) of Tank to: Dwelling **33'**
Private ☒ Public ☐ Water Source: **> 100'** Property Line: **> 100'**

ON-SITE DISPOSAL SYSTEM

Class I Systems: Standard Soil Trenches () or Bed () Gravelless Pipe (), Diameter _____ In.
Chamber Soil Absorption Trenches (☒) or Bed ()
Class II Systems: Pumped/Dosed Soil Absorption Trenches () or Bed ()
Evapotranspiration Trenches () or Bed ()
Shallow Soil Absorption Trenches () or Bed () Other: _____

No. of Lines: **4** Length (in feet) of Each: **80'**
Width of Trenches: **36** inches/feet Depth to Bottom of Field: **24** inches
If Bed, Dimensions (in feet): _____ If Chamber System, Name: _____, No. of Units: _____
Approved and Adequate Materials Used? Yes (☒) No () Size Equates to **1600** sq ft of SGF
Distance (in feet) of System to: Dwelling **50'**
Private (☒) Public () Water Source: **> 100'** Property Line: **75'**
Remarks: _____

GPS: N39 24 50.0 W78 46 33.9

An inspection indicates that
The sewage disposal system
Described above

DOES MEET ☒

DOES NOT MEET ☐ or


CANNOT BE DETERMINED TO

MEET ☐ the minimum standards
Established by the West Virginia
Bureau of Public Health.

To correct a health hazard,
Modifications to existing systems
May be done to improve part of a
System. Such modifications may
Not be able to be designated as
a Does meet system since
Inadequate information is known.

Although many factors
Contribute to the successful
Functioning of a sewage disposal
System, this office recommends
Water conservation and
Maintaining an even usage of
Water throughout the week.

Visit Date(s): _____



FINAL INSPECTION DATE: 8/26/2008

SANITARIAN: Eugene Rinker

Plat of Septic Location for
Lot 137 - Bluffs on the Potomac
Section 5

Romney District Hampshire County
West Virginia

Reference: Deed Book 467 Page 792
Map Book 10 Parcel 245
Tax Map 33 Parcel 23



Bearings on this map are based
on a Plat Recorded in MB 10/245

