

# PERMIT FOR CONSTRUCTING AN ON-SITE SEWAGE MANAGEMENT SYSTEM

## UNION COUNTY ENVIRONMENTAL HEALTH

46 Hughes Street - Suite B, Blairsville, GA 30512 ·  
Phone: (706)781-3824 · Fax: (706)835-2384

<b>Permit #:</b> 144-SM-2015-05107  <b>Application Date:</b> 05/27/2015 <b>Property Address:</b> 137 LOUDERMILK RD BLAIRSVILLE, GA 30512  <b>Lot #:</b> <b>Phase:</b> <b>Subdivision:</b> <b>Permit Type:</b> Residential	<b>Owner Information</b> <b>Owner:</b> <b>Owner's Name:</b> Donald Cady <b>Owner's Address:</b> 314 SMOKE RISE RDG BLAIRSVILLE, GA 30512  <b>Home #:</b> <b>Cell #:</b> (706) 781-5400 <b>Work #:</b> <b>Other #:</b> <b>Fax #:</b> <b>Contact by:</b> Mobile Phone <b>Email:</b>
<b>Applicant/Contact Information</b> <b>Name:</b> Donald Cady  <b>Company Name:</b> <b>Address:</b> 314 SMOKE RISE RDG BLAIRSVILLE, GA 30512  <b>Home #:</b> <b>Cell #:</b> (706) 781-5400 <b>Work #:</b> <b>Other #:</b> <b>Fax #:</b> <b>Contact by:</b> Mobile Phone <b>Email:</b>	<b>SYSTEM USE INFORMATION</b> <b>Date Structure Staked:</b> <b>Facility Type:</b> House <b>Lot Size:</b> 4.58 <b>Water Supply Approved</b> <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <b>Type:</b> Public <b>Plumbing Level:</b> Crawl Space <b>Bedrooms / GPD:</b> 3 <b>Garbage Disposal:</b> <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No <b>No. of rooms:</b> <b>Heated Sq. Ft.:</b> <b>Other Considerations:</b>
<b>Sewage Contractor:</b> 4:30 G Jones <b>Company Name:</b> <b>Soil Classifier:</b> Russell Royston <b>Company Name:</b>	

### SITE CONDITIONS

Debris Pit: ☐ Yes ☒ No                     
 Soil Type:                     
 Perc. Rate:                     
 SHWT:                     
 Rock:

Soil Classifier Recommendations:

MINIMUM SYSTEM REQUIREMENTS		SYSTEM AS INSTALLED	
Grease Trap:	D-Box Outlets:	Grease Trap:	D-Box Outlets:
Septic Tanks: #1 1000	Linear Feet:	Septic Tanks: #1 000	Linear Feet: 196'
Septic Tanks: #2	Trench Width:	Septic Tanks: #2	Trench Width: 36"
Dosing Pump Tank:	Square Feet:	Filter Manufacturer & Model: Tuffline	Square Feet:
Dosing Siphon Tank:	Reduction %:	Dosing Pump Tank:	Reduction %:
		Dosing Siphon Tank:	Reduction %: 35
Adv. Treatment Type:	Gal	Adv. Treatment Type:	Gal
Absorption Field Depth: 30" - 36"		ATS Mfg/Product Name:	
Field Layout:		Absorption Field Depth: 30-36'	
Absorption Line/Product:		Field Layout: Serial	
		Absorption Line/Product: Quick 4 Plus HC	
Additional permit requirements and installation instructions:		System as Installed Comments:	

Directions to property:

129 N, right at Ivy Log, straight thru red light, next rd on right, opposite of brick church, lot on left

Issuance of a construction permit for an on-site sewage management system and subsequent approval by representatives of the Georgia Department of Public Health or County Board of Health shall not be construed as a guarantee that such systems will function satisfactorily for a given period of time, furthermore, said representatives do not by any action in effecting compliance with these rules, assume any liability for damages which are caused, or which may be caused by the malfunction of such system.

<b>Applicant signature</b> <input checked="" type="checkbox"/> <i>Donald J. Cady</i>	<b>Date</b> 5-27-15
<b>Permit issued by:</b> <i>John Smith</i> <b>Date issued:</b> 6/2/15 <b>Status:</b> Applied for <b>Final Date:</b> 6/19/15	

MAILED 6-19-15

## FINAL APPROVAL

### APPLICATION FOR CONSTRUCTION PERMIT & INSPECTION FORM FOR ON-SITE SEWAGE MANAGEMENT SYSTEM

UNION COUNTY ENVIRONMENTAL HEALTH  
46 HUGHES STREET, SUITE B  
BLAIRSVILLE, GA 30512

Permit Number: 144-SM-2015-05107  
Property Address : Loudermilk Rd  
Owners Name: Donald Cady  
Water Supply: Public

Permit Type: New System  
Facility Type: Residence  
Bedrooms/GPD: 3  
Garbage Disposal: No

Septic Tank Installer: G. Jones

Type System Installed: Quick4Plus HC Linear Ft: 196' Trench Width: 36" Trench Depth: 30-36"

Septic Tank: 1000 Gallons Manufacturer: LA Filter: Tuff-Lite

Pump Tank: N/A Gallons Grease Trap: N/A Gallons

Distance Septic Tank From Well/Well Site: N/A Distance Drain Line From Well/Well Site: N/A

Final Approval By: [Signature] Date: 6/19/15

