

STATE OF TEXAS WELL REPORT for Tracking #267899

Owner: Matt Eppes	Owner Well #: 1
Address: PO Box 93 Fairfield, TX 75540	Grid #: 42-44-3
Well Location: CR 504 Pear Valley, TX 76867	Latitude: 31° 20' 08" N
Well County: McCulloch	Longitude: 099° 30' 32" W
	Elevation: 1573 ft. above sea level
Type of Work: New Well	
Proposed Use: Domestic	

Drilling Start Date: **8/30/2011** Drilling End Date: **8/31/2011**

	<i>Diameter (in.)</i>	<i>Top Depth (ft.)</i>	<i>Bottom Depth (ft.)</i>
Borehole:	8	0	240

Drilling Method: **Air Rotary**

Borehole Completion: **Filter Packed**

	<i>Top Depth (ft.)</i>	<i>Bottom Depth (ft.)</i>	<i>Filter Material</i>	<i>Size</i>
Filter Pack Intervals:	15	240	Gravel	

	<i>Top Depth (ft.)</i>	<i>Bottom Depth (ft.)</i>	<i>Description (number of sacks & material)</i>
Annular Seal Data:	0	15	14 portland

Seal Method: **wheel barrow**

Distance to Property Line (ft.): **over 3000**

Sealed By: **Darek Barrera lic# 58196**

Distance to Septic Field or other
concentrated contamination (ft.): **200 feet**

Distance to Septic Tank (ft.): **No Data**

Method of Verification: **measuring wheel**

Surface Completion: **Surface Slab Installed**

Water Level: 198 ft. below land surface, and 0 GPM artesian flow on 2011-09-01	Measurement Method: Unknown
---	------------------------------------

Packers: **na**

Type of Pump: **No Data**

Well Tests: **Estimated Yield: 5 GPM**

	<i>Description (number of sacks & material)</i>	<i>Top Depth (ft.)</i>	<i>Bottom Depth (ft.)</i>
Plug Information:	na		

Water Quality:

Strata Depth (ft.)

30

Water Type

clean / fresh

Chemical Analysis Made: No

Did the driller knowingly penetrate any strata which
contained injurious constituents?: No

Certification Data:

The driller certified that the driller drilled this well (or the well was drilled under the driller's direct supervision) and that each and all of the statements herein are true and correct. The driller understood that failure to complete the required items will result in the report(s) being returned for completion and resubmittal.

Company Information:

Caltex Water LLC

**4337 South Chadbourne
San Angelo, TX 76904**

Driller Name:

Bobby R Wilson

License Number: **58462**

Apprentice Name:

Billy D Arant

Apprentice Number: **58952**

Comments:

No Data

Lithology:

DESCRIPTION & COLOR OF FORMATION MATERIAL

From (ft) To (ft)

Description

0 to 10 hard brown and grey clay

10 to 40 hard grey clay

40 to 82 hard red and grey clays

82 to 100 hard grey and yellow clays

100 to 120 hard grey and red clay

120 to 160 grey and brown clays

160 to 180 hard grey clay with some tan limestone

180 to 190 tan limestone

190 to 200 tan limestone with grey clay

200 to 220 mixed grey clay and tan limestone

first water at appx 210

220 to 240 tan limestone

Casing:

BLANK PIPE & WELL SCREEN DATA

Dia. (in.) New/Used Type Setting From/To (ft.)

new 5 inch pvc screens from 240 to 180

new 5 inch pvc casing from 180 to surface