



PERMIT TO CONSTRUCT
Onsite Wastewater System

File Nbr: **2021010011**
County: Colleton

Name: MR TYLER SGRO (*Swofford*)

Program Code: 362

Type Facility: HOUSE

Address: 4524 ORR ST
N. CHARLESTON, SC 29405

System Code: 241

Subdivision:

Site: *O Lowcountry Hwy.*

TM No.: *267-00-00-003*

Block:

Lot:

Yemassee, SC 29945

Water Supply: PRIVATE

PERMIT TO CONSTRUCT SYSTEM SPECIFICATIONS

Daily Flow (gpd): 480

Tank Sizes (gal): Septic Tank: 1000

Pump Chamber: 1000

Grease Trap: 0

LTAR: .80

Trenches: Length (ft): 320

Width (in): 36

Max. Depth (in): 12

Agg. Depth (in): 6

Min Pump Capacity: 10

gpm at 15

ft. of head

Alternative Product:

SPECIAL INSTRUCTIONS/CONDITIONS

THIS PERMIT IS SITE SPECIFIC. ANY CHANGES TO THE SYSTEM MUST BE APPROVED BY DHEC. ALTERNATIVE TRENCH PRODUCTS APPROVED UNDER STATE RULES AND REGULATIONS MAY BE SUBSTITUTED. ANY UNAPPROVED CHANGES WILL VOID THIS PERMIT.

Installers must contact the local Environmental Affairs office by 10:00 AM on the day prior to installation in order to schedule a time for the final inspection.

If a Department representative does not arrive within 30 minutes of the scheduled time, the installer may conduct the final inspection.


When a contractor self-inspection occurs, the installer must complete the DHEC form 3978, Approval to Operate Contractor Self-Inspection.

The installer must submit DHEC form 3978 within 2 business days of the completion of the installation.

- * Permit issued Pursuant to Soil Report and proposed system design submitted by PSC Tyler Sgro, #119.
- * Pump is required unless gravity flow can be maintained from home to proposed drainfield area.
- * Well location 75' min. to any part of system.

PERMIT TO CONSTRUCT SYSTEM DIAGRAM

(NTS)



Issued/Revised By: *Rubens J. Threault*

Date: *1/19/2021*

This Permit is Appealable Under the Administrative Procedures Act.

This permit will expire and become null and void five (5) years from the issuance date.

There may be an Additional Fee for Changes in this Permit that Require a Site Reevaluation.

DHEC 1781 (02/2020)

Personal information provided on this form is subject to public scrutiny or release.