

HYDE COUNTY HEALTH DEPARTMENT

P.O. Box 100 Swan Quarter, N C 27885

Phone # (252) 926-4380

OPERATION PERMIT

PERMIT # 72610-2

In accordance with the provisions of Article 11 of Chapter 130A, General Statutes of North Carolina as amended, and 15A NCAC 18A .1900 et seq.:

PERMISSION IS HEREBY GRANTED TO

Mike Hawk

for the operation of a wastewater collection, treatment, and disposal system pursuant to 15A NCAC 18A .1900 et seq. and in conformity with the application, **Improvement Permit/Authorization to Construct #42110-2** and other supporting data subsequently filed and approved by the Hyde County Health Department and considered a part of this permit.

Facilities to be served: 3 bedroom house

Location: 119 Sassom Road, Scranton

The approved wastewater system consists of:

Futrell 1000 gallon septic tank with filter; Futrell 1000 gallon pump tank; 700 lin.ft. of 3" sch 80 force main; 1200 sq.ft. nitrification area consisting of 5 lines @ 80' ; pressure manifold distribution; AQWA simplex control panel, audible/visible alarm; NEMA 4X enclosure.

CONDITIONS:

1. The wastewater system shall be maintained at all times to prevent seepage or discharge of sewage or effluent to the surface of the ground or to surface waters.
2. The contents of the septic tank shall be checked every 3-5 years and the solids removed when they reach 1/3 the liquid depth of the tank.
3. Diversion or bypassing of untreated wastewater from the system is expressly prohibited.
4. Due to factors beyond the control of this department, this shall in no way be taken as a guarantee or warranty that this wastewater system will function in a satisfactory manner for any given period of time.

DATE : 7-26-10

ISSUED BY: Hugh Watson, PEHS
Environmental Health Specialist