

STATE OF TEXAS WELL REPORT for Tracking #416600

Owner: James Dewey Atwell

Owner Well #: No Data

Address: P.O. Box 351
Llano, TX 78643

Grid #: 57-10-7

Well Location: 12119 West Hwy 29
Llano, TX 78643

Latitude: 30° 45' 04.4" N

Longitude: 098° 51' 33.5" W

Well County: Llano

Elevation: No Data

Type of Work: New Well

Proposed Use: Domestic

Drilling Start Date: 3/2/2016

Drilling End Date: 3/2/2016

	Diameter (in.)	Top Depth (ft.)	Bottom Depth (ft.)
Borehole:	9.5	0	57
	6.75	57	65
	6	65	325

Drilling Method: Air Hammer

Borehole Completion: Straight Wall

	Top Depth (ft.)	Bottom Depth (ft.)	Description (number of sacks & material)
Annular Seal Data:	1	3	Cement 0.5 Bags/Sacks
	3	57	Bentonite 5 Bags/Sacks

Seal Method: Gravity

Sealed By: Driller

Distance to Property Line (ft.): 55

Distance to Septic Field or other
concentrated contamination (ft.): 1200

Distance to Septic Tank (ft.): 1200

Method of Verification: estimated

Surface Completion: Pitless Adapter Used

Surface Completion by Driller

Water Level: 32 ft. below land surface on 2016-03-03

Measurement Method: Sonic/Radar

Packers: none

Type of Pump: No Data

Well Tests: Jetted Yield: 2.5 GPM

Certification Data:	The driller certified that the driller drilled this well (or the well was drilled under the driller's direct supervision) and that each and all of the statements herein are true and correct. The driller understood that failure to complete the required items will result in the report(s) being returned for completion and resubmittal.		
Company Information:	L & L Drilling Co. P.O. Box 217 Hye, TX 78635		
Driller Name:	Gregory A. Smith	License Number:	1595
Comments:	No Data		

Lithology:			Casing:						
DESCRIPTION & COLOR OF FORMATION MATERIAL			BLANK PIPE & WELL SCREEN DATA						
Top (ft.)	Bottom (ft.)	Description	Dia (in.)	Type	Material	Sch./Gage	Top (ft.)	Bottom (ft.)	
0	2	brown sandy topsoil	6	Blank	New Plastic (PVC)	40 0.28	0	60	
2	10	brown clay							
10	39	red granite							
39	81	red & gray granite							
81	94	red granite							
90	105	water 0.5 gpm							
94	127	red & gray granite							
105	115	water 0.5 gpm							
127	248	red granite							
248	325	red & gray granite							
295	299	water 1 gpm							
309	310	water 0.5 gpm							