

To: Ernest E. Miller

Address: Route 1, Box 215,

Keyser, WV 26726

You are hereby issued a permit to install
a small sewage disposal system consisting of a septic tank and soil absorption field
and located at Push Root Road

This small sewage disposal system shall meet the following specifications:

1. Septic Tank

- a. Shall be made of pre-cast concrete and not less than 1000
gallon capacity.

2. Soil-Absorption System

- a. Shall consist of 2 distribution lines 4" in diameter.
b. Each distribution line shall be 100 100
feet in length
c. Each trench shall be 24 inch width with ZERO slope on trench bottom
and ZERO slope on each distribution line.
d. No trench shall be more than 30 inches deep.
e. Total soil-absorption area in trench bottoms shall be 400 sq. ft.
f. Filter material shall be gravel and not greater than 1/2 - 2 1/2
inches in diameter.
g. Filter material under each line shall be not less than 6 inches
deep and not less than 2 inches over each distribution line.
h. Filter material shall be covered with untreated paper prior to backfilling.
i. Trenches shall be backfilled at least 6" above ground surface to provide
for settling of backfill.

3. Other Small Sewage or Excreta Disposal Systems (Name the type system to be used,
then use back of sheet to describe the details of the system.)

4. Special Requirements

- a. Small sewage and excreta disposal systems shall be located at least 10 ft.
from any property line and a minimum of 20 ft. from any stream or roadside cut.
b. Septic tanks shall be located at least 10 ft. and excreta disposal systems
a minimum of 20 ft. from building foundation.
c. Septic tanks shall be located a minimum of 50 ft. and soil-absorption systems
and excreta disposal systems a minimum of 100 ft. from any ground water supply
or cistern.
5. This permit is not transferable and automatically expires 6 months after date
of issue.
6. The applicant or his agent must notify this department, phone 788-1321 at
least 24 hours before the system is ready for inspection.
7. All small sewage and excreta disposal systems must be inspected and approved
prior to being covered with earth or otherwise put into service. Any applicable
system or part thereof covered before being inspected shall be uncovered at the
direction of the SANITARIAN.
8. This permit is NULL AND VOID when official inspection reveals conditions
are different than those stipulated in this permit or if facts later become known
that a health hazard would result by the installation of this system.

September 24, 1982

Date of Issue

Philip S. Stiggers, M.D.
Name

Part-Time Physician Director

Title

Mineral County
Health Department

WEST VIRGINIA
SEPTIC TANK INSPECTION FORM

Mineral County Health Department Installation Permit No. ST-29-78-098

Name of Owner John Davis, Rt 1, Box 216, Keyser, W V

Address _____

Property Address 0.8 miles off Headsville Road on Pinhook Road

DESCRIPTION & NUMBER OF UNITS SERVED

Type Facility Served mobile home (12x55) No. Water Closets 1

Lot Size 4.6 ^{acres} sq. ft. Area suitable for sewage disposal installation 4 sq. ft.

Source of Water Supply drilled well No. Lavatories 1

No. Bedrooms 2 No. Showers or Tubs 1 No. Baths 1

No. Garbage Grinders 0 No. Automatic Washers 1

SEPTIC TANK

Material Pre-cast concrete Length — x Width — x Depth — = — cubic feet

Liquid Depth — ft. Liquid Capacity 750 gal.

Distance to: Dwelling 49 Water Supply 88' Nearest Property Line 60'

SOIL ABSORPTION SYSTEM

Type Drain Line Material plastic Trench Width 30 Inches

Trench Depth 24-48 Inches Total Absorption area in Trench Bottom 575 sq. ft.

Diameter of Drain Line 4 Inches Type Filter Media gravel

No. of Drain Lines 4 Depth Filter Media Under Drain Line 6 Inches

Length of Each Line 65', 65', 65', 35' ft. Depth Filter Media Over Drain Line 2 in.

Distance of Disposal Field to: (a) Dwelling 56'

(b) Water Supply 103' (c) Nearest Property Line 20'

An inspection of the septic tank system described herein disclosed that said system (MEETS, ~~DOES NOT MEET~~) the minimum standards established by the West Virginia State Department of Health.

Sept. 14, 1978
Date

Norman L. Moore, R.S.
Sanitarian

SKETCH OF SYSTEM TO BE DRAWN ON BACK

Note: Copy of this inspection report must be given to owner and the original filed in the Health Department files. PERMANENT RECORD - DO NOT DESTROY.

