



22071 Fisk Rd Noti, OR 97461  
541-935-7867 541-997-7867

Date :08/05/2016

Location: 25750 Butler Raod  
Junction City, OR

Time	Gallons Per Min.	Static Water Level		
8:45	12	unknown	Well Depth In Ft.	
9:00	12		Inches Above Grade	6
9:15	12		Well diameter	6
9:30	12		Pump Hp	
9:45	12		Amps	
10:00	12		Avarage Flow	
10:15	12			
10:30	12		Hardness	
10:45	12		PH	
11:00	11		Iron	
11:15	11			
11:30	11			
11:45	11			
12:00	11			
12:15	10			
12:30	10			
12:45	10			



Delivering more than  
just test results

ALG ORELAP ID #OR100012

361 West 5th Ave

Eugene, OR 97401

TEL: (541) 485-8404 FAX: (541) 484-5995

Website:

# Analytical Report

Date Reported: 8/8/2016

**WO#:** 1608306  
**CLIENT:** Coastal Range Water Inc.  
**Location:** 25750 Butler Road; Junction City, OR  
**Project:**  
**Sample Source:** Well

**Received Date:** 8/5/2016 10:00:00 AM  
**Sampler Name:** Andy Cobb  
**Matrix:** Drinking Water  
**Treatment:** Untreated

**Lab ID:** 1608306-001 **Client Sample ID:** Kitchen **Collection Date:** 8/5/2016 8:30:00 AM

Analyses	Method	ORELAP		Analyst	RL	MCL	Result	Units	Qual
		Status	Date Analyzed						
Nitrate-N	EPA 300.0	A	08/05/2016 14:52	AS	0.100	10.0	ND	mg/L	
Arsenic	SM 3113 B	A	08/07/2016 7:53	KG	0.00200	0.0100	ND	mg/L	
Coliform, Total	SM 9223B	A	08/05/2016 12:03	JL	0	Absent	Absent	P/A	
E. coli	SM 9223B	A	08/05/2016 12:03	JL	0	Absent	Absent	P/A	

*Kimberly J. Reeve Morghan*

Kimberly Reeve Morghan  
Quality Manager

**Definitions:** A Accredited by ORELAP  
LOD Limit of Detection  
MCL Maximum Contaminant Level  
ND Not Detected at the Reporting Limit  
PL Permit Limit  
RL Reporting Detection Limit

**Qualifiers:**

## SP\*45292-690