Hampshire County Health Department On-Site Sewage Disposal System Inspection Form

Permit # ST-14-08-10(
Name of Owner: Raymond & Wendolyn Reed Installer: Ed Shoemaker
Address: 1982 Crystal Rd, Hartly, Delaware 19953
Property Location: Deerfield Highlands Lot 16 Lot Size: 5.097AC Acres
Type of Facility: Facility is: X New Existing
Design Loading in gpd/# Bedrooms: 3 Source of Water: Well
SEWAGE TANK COMPONENT
Capacity in Gallons: 1000 Material: precast concrete Manufacturer:
Pump Chamber gal
Distances (in feet) of Tank to: Dwelling Not Constructed
Private Public Water Source: Property Line: 50'
ON-SITE DISPOSAL SYSTEM
Class I Systems: Standard Soil Trenches() or Bed() Gravelless Pipe(), Diameter In.
Chamber Soil Absorption Trenches (X) or Bed()
Class II Systems: Pumped/Dosed Soil Absorption Trenches () or Bed ()
Evapotranspiration Trenches () or Bed ()
Shallow Soil Absorption Trenches () or Bed () Other:
No. of Lines: 4 Length (in feet) of Each: 60'
Width of Trenches: 36 inches/feet Depth to Bottom of Field: 24-30 inches
If Bed, Dimensions (in feet): If Chamber System, Name:, No. of Units:
Approved and Adequate Materials Used? Yes (X) No () Size Equates to 1200 sq ft of SGF
Distance (in feet) of System to: Dwelling Private () Public ()
Water Source: Property Line: 15'
Remarks: Dwelling/well not constructed at time of inspection_
GPS: N39 12 52.5 w78 53 31.3
An inspection indicates that The sewage disposal system North S)P Road
An inspection indicates that
The sewage disposal system Described above
DOES MEET X
DOES NOT MEET or
CANNOT BE DETERMINED TO
MEET the minimum standards
Established by the West Virginia Bureau of Public Health
To correct a health hazard,
Modifications to existing systems
May be done to improve part of a
System. Such modifications may
Not be able to be/designated as \ \ \ \ \ \ \ \ \ \ \ \ \ \ \ \ \ \
Inadequate information is known.
Although many factors
Contribute to the successful
Functioning of a sewage disposal
System, this office recommends Water conservation and
Maintaining an even usage of
Water throughout the week.
Visit Date(s):
F151
$\sim \sim $
FINAL INSPECTION DATE: 4/17/2008 SANITARIAN: Sun //// (en //)