NOTICE TO WATER WELL CONTRACTOR The original and first copy of this report are to be

State Well No. 55/4W-8ab

STATE ENGINEER, SALEM, OREGON 97310 within 30 days from the date of well completion.

filed with the

STATE OF OREGON NOV 1 3 1974

STATE OF OREGON NOV 1 3 1974

(Please type or print) STATE ENGINEER

(Do not write above this line ALEM, OREGON)

STATE OF OREGON

STATE ENGINEER

(Do not write above this line ALEM, OREGON)

***		
(1) OWNER:	(10) LOCATION OF WELL:	
Name Gary Hurley	County Yamhill Driller's well num	ıber
Address Rte. 1 Box 199A., McMinnville, Or	NW4 NE4 Section 8 T. 5S I	r. 4W w.m.
	Bearing and distance from section or subdivision	ı corner
(2) TYPE OF WORK (check):		
New Well 🛚 Deepening 🗌 Reconditioning 🖂 Abandon 🗔		
f abandonment, describe material and procedure in Item 12.	(11) WATER LEVEL: Completed we	11.
(3) TYPE OF WELL: (4) PROPOSED USE (check):	Depth at which water was first found 52 ft.	
Rotary Driven Domestic M Industrial Municipal		rface. Date NOV. 8-
Cable		
oug [] Doled [] Highwan [] Tone [] Outer []	Artesian pressure lbs. per square	mcn. Date
CASING INSTALLED: Threaded   Welded	(12) WELL LOG: Diameter of well be	low casing 0
" Diam. from	Depth drilled 72 ft. Depth of completed well 70 ft.	
" Diam. from ft. to ft. Gage	Formation: Describe color, texture, grain size an	
" Diam. from ft. to ft. Gage	and show thickness and nature of each stratum and aquifer penetrated,	
PERFORATIONS: Perforated? * Yes   No.	with at least one entry for each change of formation position of Static Water Level and indicate principles.	
Manach		
7/0	MATERIAL TODSOLL	From To SWL
Size of perforations 1/8 in. by 12 in.	Brown & Yellow Clay	2 41
perforations from it, to it.	Brown Sand and Fine	2 44
perforations from ft. to ft.	Gravel	41 48
perforations from ft. to ft.	Sandy Blue Clay	48 52
(7) SCREENS: Well screen installed? □ Yes 本No	Coarse Brown Sand w/	
Manufacturer's Name	Med. Gravel	52 64
Type Model No	Med. Blue Gravel and	
Diam Slot size Set from ft. to ft.	Coarse Sand	64 72
Diam Slot size Set from ft. to ft.		
(8) WELL TESTS: Drawdown is amount water level is		
lowered below static level		
Was a pump test made? ☐ Yes ☐ No If yes, by whom?		
Yield: gal./min. with ft. drawdown after hrs.		
" "		
n n		-
Bailer test 20 gal./min. with 25 ft. drawdown after 1 hrs.	, , , , , , , , , , , , , , , , , , , ,	
Artesian flow g.p.m.		
nperature of water 52 Depth artesian flow encountered ft.	Work started NOV . 6 1974 Completed	Nov. 8 19 74
	Date well drilling machine moved off of well	Nov. 8 19 74
(9) CONSTRUCTION:		
well seal—Material used <u>Cement Grout</u>	Drilling Machine Operator's Certification: This well was constructed under my	direct supervision
Well sealed from land surface to $\frac{20}{100}$ ft.	······ Tt.   Materials used and information reported above are true to my	
Diameter of well bore to bottom of seal in.	best knowledge and belief. \ \ //	
Diameter of well bore to bottom of seal	[Signed   Mel   Miller   Date Nov. 9, 1974.	
Number of sacks of cement used in well sealsacks	Drilling Machine Operator's License No	172
Number of sacks of bentonite used in wen searsacks		
Brand name of bentonite	Water Well Contractor's Certification:	
Number of pounds of bentonite per 100 gallons of waterlbs./190 gals.	This well was drilled under my jurisdiction and this report is	
Was a drive shoe used? ☐ Yes ☑No Plugs Size: location ft.	true to the best of my knowledge and belief.	
Did any strata contain unusable water?   Yes   No	(Person, firm or corporation) (Type or print)	
pe of water? depth of strata Address P. O. Box 569, McMinnville, Ore.		
Method of sealing strata off	(1, -1, 1/1n/ 1/1/10)	
Was well gravel packed? N Yes \( \Delta \) No Size of gravel: 3/8 Pea	[Signed A Water Well Contra	etor)
	Contractor's License No. 428 Date	
Gravel placed from ft. to ft.	· · · · · · · · · · · · · · · · · · ·	
(USE ADDITIONAL SE	(EETS IF NECESSARY)	SP*45656-119