



State License No. C57 432680
P.O. BOX 845
ATASCADERO, CA 93423
805-466-1271

Name NATALIE CROSS
Mailing Address 6320 VINEYARD DRIVE - PASO ROBLES, CA 93446
Job Location 6320 VINEYARD DRIVE - PASO ROBLES, CA 93446
Well Size 5" Depth 156'
Tested by M.BOLLINGER Rate of Flow (gpm) 16
Pump 140

Date 9/2/2021
Phone 808-280-0923
APN 039-061-032
Duration 4 HOUR + RECOVERY
Static Level 89.6'

Well Test Report

<u>Date</u>	<u>Time</u>	<u>Water Level (FT)</u>	<u>G.P.M.</u>	<u>Drawdown</u>
9/1/2021	8:30AM	89.6	18.0	
	8:35	124.9	18.0	-35.3
	8:40	125.0	18.0	-35.4
	8:45	121.7	16.0	-32.1
	9:00	113.2	16.0	-23.6
	9:15	113.7	16.0	-24.1
	9:30	113.7	16.0	-24.1
	9:50	113.8	16.0	-24.2
	10:10	113.8	16.0	-24.3
	10:30	113.9	16.0	-24.3
	10:50	114.1	16.0	-24.5
	11:10	114.2	16.0	-24.6
	11:30	114.2	16.0	-24.6
	11:50	114.2	16.0	-24.6
	12:10PM	114.3	16.0	-24.7
	12:30	114.5	16.0	-24.9

Recovery

<u>Date</u>	<u>Time</u>	<u>Water Level (FT)</u>
9/1/2021	12:30PM	114.5
	12:35	94.6
	12:40	90.2
	12:45	89.6

Additional Comments:

Thank you,

Ned M. Thompson

Ned M. Thompson

State License No. C57 432680
P.O. BOX 845
ATASCADERO, CA 93423
805-466-1271

Abalone Coast Analytical, Inc.

141 Suburban Rd, Ste C-1 San Luis Obispo CA, 93401
Phone: 595-1080 Fax: 595-1075

Order #: 21-4251

Date/Time Rec'd: 9/2/21 1438

Filipponi & Thompson Drilling
P.O. Box 845
Atascadero, CA 93423

Contact: Ned Thompson
Phone: 805-466-1271
Sampler: Andrew Puller

Project: Cross

Sample #	Sample Description	Date / Time	Analysis	Method	Result	Units	RL	Completed
-1	6320 Vineyard Drive	9/2/21 1220	MPN Total Coliform	SM 9223 B.	ND.	MPN/100mL	1	09/03/21
			MPN E-coli	IDEXX	ND.	MPN/100mL	1	09/03/21

This sample passes water quality standards for Total Coliform and E. Coli Bacteria.

Report Completion Date:

9/3/21

Reviewed By:



Amanda Smith, Lab Director

Definitions:

MPN = Most Probable Number

RL = Reporting Limit

ND = Analyte NOT DETECTED at or above MDL

State of California CDPH ELAP 2661

Coliform are bacteria that are naturally present in the environment and are used as an indicator that other, potentially-harmful, bacteria may be present.

The presence of Fecal coliforms and/or *E. coli* indicates that the water may be contaminated with human or animal wastes. Microbes in these wastes can cause short-term effects, such as diarrhea, cramps, nausea, headaches, or other symptoms. They may pose a special health risk for infants, young children, some of the elderly, and people with severely compromised immune systems.