

n

From: Ashli Badders <abadders@co.kerr.tx.us>
Sent: Tuesday, August 24, 2021 2:34 PM
To:
Cc:
Subject: RE: request for septic info for 131 Thrill Hill

Good afternoon, Mr. & Mrs. Eggert:

Apologies for the late response. Thank you for taking the time to outline the timeline of the property. With your written statement, we will not require for the system to be permitted and consider the OSSF installed under the 10-acre exception criteria for one single-family dwelling, and as long all septic components are 100 feet from the property line. Please let us know if you have any questions. Thank you.

Ashli S. Badders

Designated Representative OS30795

Kerr County Environmental Health Director

700 Main St., BA-100

Kerrville, TX 78028

PH. 830-896-9022 x1144
