

File Original with DWR

Page 1 of 1

Owner's Well Number 1

Date Work Began 02/27/2013 Date Work Ended 3/7/2013

Local Permit Agency Tehama County Environmental Health Dept.

Permit Number W-230-12 Permit Date 12/13/13

Well Completion Report

State of California
Refer to Instruction Pamphlet
No. e0173052

DWR Use Only - Do Not Fill In

State Well Number/Site Number									
Latitude					Longitude				
APN/TRS/Other									

Geologic Log

Orientation		Specify
☒ Vertical	☐ Horizontal	☐ Angle
Drilling Method		Drilling Fluid
Direct Rotary		Fresh Water
Depth from Surface		Description
Feet	to Feet	Describe material, grain size, color, etc
0	10	Dirt & sand
10	40	Gravel & Sand
40	65	Clay
65	90	Gravel
90	105	Clay
105	120	Gravel
120	135	Clay
135	160	Gravel
160	175	Clay
175	200	Gravel
200	230	Clay
230	235	Clay with gravel
235	265	Clay
Total Depth of Boring		265 Feet
Total Depth of Completed Well		220 Feet

Well Owner


Name Charles and Terri Sullivan
Mailing Address P.O. Box 1448
City Corning State CA Zip 96021

Well Location

Address Black Butte Road, 1 mi. West of Newville Rd.
City Corning County Tehama
Latitude Dec. Min. Sec. N Longitude Dec. Min. Sec. W
Datum Decimal Lat. Decimal Long.
APN Book 085 Page 260 Parcel 11-1
Township Range Section

Location Sketch

(Sketch must be drawn by hand after form is printed.)



Illustrate or describe distance of well from roads, buildings, fences, rivers, etc. and attach a map. Use additional paper if necessary. Please be accurate and complete.

Activity

- ☒ New Well
☐ Modification/Repair
☐ Deepen
☐ Other
☐ Destroy
Describe procedures and materials under "GEOLOGIC LOG"

Planned Uses

- ☒ Water Supply
☒ Domestic ☐ Public
☐ Irrigation ☐ Industrial
☐ Cathodic Protection
☐ Dewatering
☐ Heat Exchange
☐ Injection
☐ Monitoring
☐ Remediation
☐ Sparging
☐ Test Well
☐ Vapor Extraction
☐ Other

Water Level and Yield of Completed Well

Depth to first water (Feet below surface)
Depth to Static
Water Level 130 (Feet) Date Measured 03/07/2013
Estimated Yield * 35 (GPM) Test Type Air Lift
Test Length 4.0 (Hours) Total Drawdown (Feet)
*May not be representative of a well's long term yield.

Casings

Depth from Surface	Borehole Diameter	Type	Material	Wall Thickness	Outside Diameter	Screen Type	Slot Size
Feet to Feet	(Inches)			(Inches)	(Inches)		If Any (Inches)
0	180	12	Blank	PVC	cl-200	5	
180	220	12	Screen	PVC	cl-200	5	Milled Slots 0.032

Annular Material

Depth from Surface	Fill	Description
Feet to Feet		
0	22	Bentonite
22	220	Filter Pack
		1/4" x 1/8" birdseye gravel

Attachments

- ☐ Geologic Log
☐ Well Construction Diagram
☐ Geophysical Log(s)
☐ Soil/Water Chemical Analyses
☐ Other

Attach additional information, if it exists.

Certification Statement

I, the undersigned, certify that this report is complete and accurate to the best of my knowledge and belief
Name Sullivan Drilling, Inc.

Person, Firm or Corporation
P.O. Box 1227 Orland CA 95963

Signed Charles Sullivan City State Zip
3/22/2013 656504

C-57 Licensed Water Well Contractor Date Signed C-57 License Number