

PERMIT TO CONSTRUCT

Onsite Wastewater System

File Nbr 2019010059

County: Greenville

Name: AM KABAN

Type Facily: HOUSE

Subdivision: HOLCOMBE RIDGE

Block: 3 BEDROOMS

Lot: E/35

Address: 16 DANIEL DR

MATAWAH, NJ 07747

Site: 3

35 JASLIN LN

TRAVELERS REST, SC 29690

Program Code: 360

9

System Code: 100

TM#: 0662.08-01-010.04

Water Supply: PUBLIC

PERMIT TO CONSTRUCT SYSTEM SPECIFICATIONS

Daily Flow (gpd): 360

Tank Sizes (gal): Septic Tank: 1000

Pump Chamber:

Grease Trap:

LTAR: .40

Trenches:Length (ft): 300

Width (in): 36

Max. Depth (in): 48

Agg. Depth (in): 14

Min Pump Capacity:

gpm at

ft. of Head

SPECIAL INSTRUCTIONS/CONDITIONS

THIS PERMIT IS SITE SPECIFIC. ANY CHANGES TO THE SYSTEM MUST BE APPROVED BY DHEC. ALTERNATIVE TRENCH PRODUCTS APPROVED UNDER STATE RULES AND REGULATIONS MAY BE SUBSTITUTED. ANY UNAPPROVED CHANGES WILL VOID THIS PERMIT.

Follow all applicable sections of Regulation 61-56 when installing system. Maintain 5' setback from foundation. Use serial distribution and run drainfield lines on contour. Do not park, drive or build over septic system.

Chite where side side of slope or ridge.

The strong stron

Issued/Revised By:

Why

_

Date: 2-22-19

DHEC 1781 (01/2014)

This Permit is Appealable Under the Administrative Procedures Act.

There may be an Additional Fee for Changes in this Permit that Require a Site Reevaluation.