



## **Hampshire County Health Department**

**HC 71, Box 9**

**Augusta, WV 26704**

**Nursing (304) 496-9640**

**Environmental (304) 496-9641**

**Fax: (304) 496-9650**

**September 21, 2006**

Hampshire County Planning Commission  
PO Box 883  
Romney, WV 26757

Dear Sirs;

This office has reviewed an application for Michael A. Corbin to approve Lot 5 of Patterson Estates located off Sand Hill Road, and further referenced as District 7, Tax Map 20, Parcel 50, Deed book 453, Page 441. This lot consists of 24.546 acres.

All lots require a percolation test and a sewage disposal area of 10,000 square feet where no development or structures other than the septic system shall be permitted. This lot is to be developed with an individual well and septic to serve a single-family dwelling.

Percolation test results are within limits as set forth by West Virginia CSR 16-1. Six feet soil observation holes indicate no restrictions due to water table or shallow bedrock within the designated sewage disposal area except as noted on the Health Department subdivision application.

The application dated 9/14/06 is hereby approved by the Hampshire County Health Department. Any changes or revisions to the Health Department stamped and signed plat, or subsequent final plats approved based upon the approved plat, will make this approval null and void.

This approval is **not** a permit for individual water systems or individual sewer systems. Applications for permits must be made separately to the Hampshire County Health Department.

Sincerely,

A handwritten signature in cursive script, appearing to read "Terry Mayhew".

Terry Mayhew R.S.

cc: Michael A. Corbin

Subdivision Name Patterson Estates County Hampshire  
Total Number of Lots \_\_\_\_\_ Name of Applicant Michael Corbin  
Name of Certified Installer Responsible for Testing T+B Excavating  
Installer Certification No. 54-05-0015 Installer Signature Brian Dawkins  
Address P.O. Box 308 Augusta WV 26704

[illegible]

(Attach additional pages if needed)