

## STATE OF TEXAS WELL REPORT for Tracking #562702

Owner:	<b>Ryan Rodenberg</b>	Owner Well #:	<b>#380</b>
Address:	<b>Lot 22 Stoneledge Pass Blanco, TX 78606</b>	Grid #:	<b>57-54-8</b>
Well Location:	<b>Lot 22 Stoneledge Pass Blanco, TX 78606</b>	Latitude:	<b>30° 07' 42" N</b>
Well County:	<b>Blanco</b>	Longitude:	<b>098° 18' 49" W</b>
		Elevation:	<b>1505 ft. above sea level</b>
Type of Work:	<b>New Well</b>	Proposed Use:	<b>Domestic</b>

Drilling Start Date: **11/9/2020**      Drilling End Date: **11/9/2020**

	<i>Diameter (in.)</i>	<i>Top Depth (ft.)</i>	<i>Bottom Depth (ft.)</i>
Borehole:	<b>11</b>	<b>0</b>	<b>3</b>
	<b>9</b>	<b>3</b>	<b>544</b>

Drilling Method: **Air Hammer**

Borehole Completion: **Filter Packed**

	<i>Top Depth (ft.)</i>	<i>Bottom Depth (ft.)</i>	<i>Filter Material</i>	<i>Size</i>
Filter Pack Intervals:	<b>50</b>	<b>544</b>	<b>Gravel</b>	<b>3/8</b>

	<i>Top Depth (ft.)</i>	<i>Bottom Depth (ft.)</i>	<i>Description (number of sacks &amp; material)</i>
Annular Seal Data:	<b>0</b>	<b>50</b>	<b>Cement 12 Bags/Sacks</b>

Seal Method: **Tremie**

Sealed By: **Driller**

Distance to Property Line (ft.): **86**

Distance to Septic Field or other  
concentrated contamination (ft.): **150**

Distance to Septic Tank (ft.): **100**

Method of Verification: **No Data**

Surface Completion: **Surface Sleeve Installed**      **Surface Completion by Driller**

Water Level: **No Data**

Packers: **No Data**

Type of Pump: **Submersible**      Pump Depth (ft.): **520**

Well Tests: **Jetted**      **Yield: 7 GPM**

Water Quality:

<i>Strata Depth (ft.)</i>	<i>Water Type</i>
<b>340 - 520</b>	<b>No Data</b>

Chemical Analysis Made: **No**

Did the driller knowingly penetrate any strata which  
contained injurious constituents?: **No**

Certification Data: The driller certified that the driller drilled this well (or the well was drilled under the driller's direct supervision) and that each and all of the statements herein are true and correct. The driller understood that failure to complete the required items will result in the report(s) being returned for completion and resubmittal.

Company Information: **Spring Branch Water Well Service**  
**8567 US HIGHWAY 281 N**  
**Spring Branch, TX 78070**

Driller Name: **Ernest V. Haack IV**

License Number: **59587**

Comments: **No Data**

Lithology:  
DESCRIPTION & COLOR OF FORMATION MATERIAL

Casing:  
BLANK PIPE & WELL SCREEN DATA

<i>Top (ft.)</i>	<i>Bottom (ft.)</i>	<i>Description</i>
<b>0</b>	<b>10</b>	<b>Tan Limestone</b>
<b>10</b>	<b>70</b>	<b>Gray Shale/clay void @ 25</b>
<b>70</b>	<b>160</b>	<b>Gray/Tan Limestone</b>
<b>160</b>	<b>235</b>	<b>Tan Gray Limestone</b>
<b>235</b>	<b>245</b>	<b>Gray Shale/clay</b>
<b>245</b>	<b>320</b>	<b>Gray/Tan Sandstone/Clay</b>
<b>320</b>	<b>500</b>	<b>Tan/Gray Sandstone 340-360 H2O 420 H2O</b>
<b>500</b>	<b>520</b>	<b>Tan Sandstone</b>
<b>520</b>	<b>544</b>	<b>Gray/Tan Sandstone H2O</b>
<b>544</b>	<b>544</b>	<b>TD</b>

<i>Dia (in.)</i>	<i>Type</i>	<i>Material</i>	<i>Sch./Gage</i>	<i>Top (ft.)</i>	<i>Bottom (ft.)</i>
<b>4.5</b>	<b>Blank</b>	<b>New Plastic (PVC)</b>	<b>SDR17</b>	<b>-2</b>	<b>380</b>
<b>4.5</b>	<b>Perforated or Slotted</b>	<b>New Plastic (PVC)</b>	<b>0.035</b>	<b>380</b>	<b>420</b>
<b>4.5</b>	<b>Blank</b>	<b>New Plastic (PVC)</b>	<b>SDR17</b>	<b>420</b>	<b>480</b>
<b>4.5</b>	<b>Perforated or Slotted</b>	<b>New Plastic (PVC)</b>	<b>0.035</b>	<b>480</b>	<b>540</b>

---

**IMPORTANT NOTICE FOR PERSONS HAVING WELLS DRILLED CONCERNING CONFIDENTIALITY**

TEX. OCC. CODE Title 12, Chapter 1901.251, authorizes the owner (owner or the person for whom the well was drilled) to keep information in Well Reports confidential. The Department shall hold the contents of the well log confidential and not a matter of public record if it receives, by certified mail, a written request to do so from the owner.

Please include the report's Tracking Number on your written request.

**Texas Department of Licensing and Regulation  
P.O. Box 12157  
Austin, TX 78711  
(512) 334-5540**