

STATE OF TEXAS
WATER WELL REPORT

ATTENTION OWNER: Confidentiality
Divulge Notice on Reverse Side

OWNER: DAVIS, GINGER ADDRESS: P.O. BOX 1223 CITY: JOHNSON CITY STATE: TX ZIP: 78636-5

ADDRESS OF WELL:
County: BLANCO GRID # 57-44-5
Street or RFD: FM 2721
City, State, Zip code: JOHNSON CITY TX 78636-

TYPE OF WORK: NEW WELL 4) PROPOSED USE: DOMESTIC
If Public Supply well, were plans submitted to the TNECC?

WELL LOG: 00953 DIAMETER OF HOLE 7) DRILLING METHOD: 8) BOREHOLE COMPLETION:

DATE DRILLING:	DIAMETER	FROM	TO	AIR HAMMER	GRAVEL PACKED	IF GRAVEL...	FROM	TO	FT.
STARTED: 01/19/99	9.00	0	130				40	130	FT.
COMPLETED: 01/19/99	6.75	130	148						
	6.00	148	202						

CASING, BLANK PIPE, AND WELL SCREEN DATA:

DIA	NEW/USED	DESCRIPTION	FROM	TO	GAGE CASING SCREEN
6	N	PLASTIC SOLID	0	110	.280
6	N	PLASTIC SLOTTED	110	134	.280

9) CEMENTING DATA:

Cemented from 1 FT. TO 40 FT. No. of Sacks Used 3

Method used: GRAVITY CEMENTED
Cemented by: L & L DRILLING CO.
Distance to septic field lines: 150 ft.
Method of verification of above distance: ESTIMATED

10) SURFACE COMPLETION:
PITLESS ADAPTOR USED

11) WATER LEVEL:
STATIC LEVEL: 67 FT. DATE: 01/19/99
ARTESIAN FLOW: GPM. DATE:

12) PACKERS: TYPE DEPTH

13) TYPE PUMP: 14) WELL TEST:
JETTED
DEPTH TO PUMP: YIELD: 17 GPM WITH FT DRAWDOWN AFTER HRS

15) WATER QUALITY: DEPTH OF STRATA: 16 GRAINS OF HARDNESS
TYPE OF WATER: NO STRATA OF UNDESIRABLE WATER PENETRATED 480 T.D.S.

CHEMICAL ANALYSIS MADE

COMPANY NAME: L & L DRILLING CO. WATER WELL DRILLER'S LICENSE NO.: 1595 FOR TWC USE ONLY
ADDRESS: DRAWER 217 CITY: HYE, STATE: TX ZIP CODE: 78635 WELL NO. _____
LOCATED ON MAP _____

I HEREBY CERTIFY THAT THIS WELL WAS DRILLED BY ME (OR UNDER MY SUPERVISION) AND THAT EACH AND ALL OF THE STATEMENTS HEREIN ARE TRUE TO THE BEST OF MY KNOWLEDGE AND BELIEF. I UNDERSTAND THAT FAILURE TO COMPLETE ITEMS 1 THRU 15 WILL RESULT IN THE LOG(S) BEING RETURNED FOR COMPLETION AND RESUBMITTAL.

(signed) Gregory A. Smith (signed) _____
(REGISTERED WATER WELL DRILLER) (REGISTERED DRILLER TRAINER)