

J.T. Robinett and Sons Water Well Drilling and Pump Service
508 Echo Valley Rd
Salinas, CA 93907
office@jtrobinettandsons.com

831-663-2493 PH
831-663-5027 FAX

WELL & PUMP EXAMINATION

Date: June 09, 2023

Well Location: 32650 Johnson Cyn Rd Gonzales, CA 93926
Attn: Kelly

Well Test: 1 Hour
Single Family Well: Domestic
Well Produced (GPM): 18.5 GPM
Submersible Pump: ½ HP
Pumping Level: est 40 feet
Well Draw Down: 10 feet
Well Depth: est 85 – 100 feet
Storage Tank: qty 2 – 5,000 gallon storage tanks
Casing: 6 inch Steel Casing

Test Results:
1:20 PM – Start Test
1:24 PM – 18.5 GPM
1:34 PM – 18.5 GPM
1:44 PM – 18.5 GPM
1:54 PM – 18.5 GPM
2:04 PM – 18.5 GPM
2:14 PM – 18.5 GPM
2:24 PM – Stop Test

Comments: Well is in good condition.