STATE OF TEXAS WELL REPORT for Tracking #33605

Owner: Charlie Hill Owner Well #: 1

Address: 15134 Chestnut Falls Drive Grid #: 57-21-6

Cypress, TX 77433

Well Location: Hoover Valley

Latitude: 30° 42' 19" N

Burnet, TX 78611 Longitude: 098° 23' 17" W

Well County: Burnet Elevation: No Data

Type of Work: New Well Proposed Use: Domestic

Drilling Start Date: 10/28/2003 Drilling End Date: 10/28/2003

 Diameter (in.)
 Top Depth (ft.)
 Bottom Depth (ft.)

 Borehole:
 8
 0
 20

 6
 20
 125

Drilling Method: Air Hammer

Borehole Completion: Straight Wall

Annular Seal Data:

Top Depth (ft.)

Bottom Depth (ft.)

Description (number of sacks & material)

4

Seal Method: Slurry Distance to Property Line (ft.): 50+

Sealed By: APEX Drilling Inc Distance to Septic Field or other

concentrated contamination (ft.): 150+

Distance to Septic Tank (ft.): No Data

Method of Verification: landowner

Surface Completion: Surface Sleeve Installed

Water Level: No Data

Packers: Burlap 40', 20'

Type of Pump: No Data

Well Tests: Estimated Yield: 35 GPM

Water Quality: Strata Depth (ft.) Water Type

Water Quality: 87-116 Granite

Chemical Analysis Made: No

Did the driller knowingly penetrate any strata which contained injurious constituents?: **No**

Certification Data: The driller certified that the driller drilled this well (or the well was drilled under the

driller's direct supervision) and that each and all of the statements herein are true and correct. The driller understood that failure to complete the required items will result in

the report(s) being returned for completion and resubmittal.

Company Information: APEX Drilling, Inc.

PO Box 867

Marble Falls, TX 78654

Driller Name: Michael G. Becker, P.G. License Number: 54516

Comments: No Data

Lithology: DESCRIPTION & COLOR OF FORMATION MATERIAL

Casing: BLANK PIPE & WELL SCREEN DATA

| Top (ft.) | Bottom (ft.) | Description |
|-----------|--------------|---------------------|
| 0 | 21 | Gravel-Granite |
| 21 | 40 | Broken Pink Granite |
| 40 | 83 | Granite Gravel |
| 83 | 125 | Granite Bedrock |
| 87 | 88 | Fracture |
| 93 | 98 | Fracture |
| 115 | 116 | Fracture |

| Dia. (in.) New/Used | Type | Setting From/To (ft.) | | |
|-------------------------------------|------|-----------------------|--|--|
| 4.5" (5"OD) New PVC +2 to 125 Sch40 | | | | |

IMPORTANT NOTICE FOR PERSONS HAVING WELLS DRILLED CONCERNING CONFIDENTIALITY

TEX. OCC. CODE Title 12, Chapter 1901.251, authorizes the owner (owner or the person for whom the well was drilled) to keep information in Well Reports confidential. The Department shall hold the contents of the well log confidential and not a matter of public record if it receives, by certified mail, a written request to do so from the owner.

Please include the report's Tracking Number on your written request.

Texas Department of Licensing and Regulation P.O. Box 12157 Austin, TX 78711 (512) 334-5540