

Pump

CERTIFICATE OF COMPLETION

8754-96-4639
MADISON COUNTY HEALTH DEPARTMENT

Property Owner: William & Roberta Roulas Phone: 516.9011

Property Address: 140 Health Care Lane

Location: Hwy 63 Access from Hub of Grace on (R) Date: 5-10-01

Subdivision: Section: Lot Number:

New Septic Tank System ☒ Tank Material: Concrete ☒ Other ☐ Manufacturer: Atacme

Built In Place Tank: Material Inside Dimensions: Length Width Liquid Capacity: 1000 gal

Nitrification Field: Square Footage 960' Lines 3 Length 110'/120'90' Width 3' Depth of Gravel 0' Liquid Capacity

Other Type Disposal: Polystone aggregate (E-2 flow system)

Repair To Existing System ☐ Existing Tank: Yes ☐ No ☐ Material: Concrete ☐ Block ☐ Other ☐ New Tank ☐ Gal. Liquid Capacity

Nit. Field: Existing Square Footage Square Footage Added Total Sq. Footage No. Lines Length Width

SYSTEM DESIGNED FOR:

Residence ☒ Bedrooms 4 Mobile Home ☐ Bedrooms Other Establishment ☐ Type

Basement: Yes ☒ No ☐

Nearest Distance To Water Supply 50' Stream 50' Foundation 15' Property Line 10' Installed By: Ken Dangle

Remarks: Keep all surface water away from system. Polystone aggregate system & E-2 flow

Approved: Yes ☒ No ☐ Sanitarian James Dot BS #1408 Notice: This approval is issued subject to all the provisions of Rules and Regulations governing the design, installation, cleaning, and maintenance of sewage disposal systems in Madison County, Section 1900 of the North Carolina Administrative Code, and Chapter 130, Article 13E of the General Statutes of North Carolina. No person is permitted to make alterations in the design or use of this system other than its designated use without approval of an authorized sanitarian. This approval indicates that this system has been installed in compliance with the standards as set forth in the above regulations, but shall in no way be taken as a guarantee that the system will function satisfactorily for any given period of time.

