



James Radcliff <jamie@teriradcliff.com>

10629 Versailles- Tract 3 Septic revision

4 messages

James Radcliff <jamie@teriradcliff.com>

Sat, May 25, 2024 at 10:30 PM

To: Sean.Antoniak@tn.gov

Sean,

This follows the contour better according to installer. The yellow portions are hard pipe. Installer says tank outlet height is 24" higher than field line so pump tank deletion is requested. Thoughts?

Thank you!

Lot 3

Antoniak

/8/2023

- All electric components (e
subsurface sewage disposal
approved by the appropri
requesting a final inspectio
inspection must be availabl


Hard pipe

Delete pump
Tank b/c 24"
Fall per 100 ft

Sc
Co

House

↓ 5 min



Sean Antoniak <Sean.Antoniak@tn.gov>
To: James Radcliff <jamie@teriradcliff.com>

Tue, May 28, 2024 at 9:43 AM

That looks fine. This email allows you to go ahead as requested. The final inspection will reflect the changes.

Thanks,

Sean Antoniak

Sent from [Mail](#) for Windows 10

From: James Radcliff
Sent: Saturday, May 25, 2024 10:31 PM
To: Sean Antoniak
Subject: [EXTERNAL] 10629 Versailles- Tract 3 Septic revision

***** This is an EXTERNAL email. Please exercise caution. DO NOT open attachments or click links from unknown senders or unexpected email - STS-Security. *****

Sean,

This follows the contour better according to installer. The yellow portions are hard pipe. Installer says tank outlet height is 24" higher than field line so pump tank deletion is requested. Thoughts?

Thank you!

10629 Versailles Rd
M 146 P 054.00
Lot 3

Antoniak



/8/2023

Please refer to the design
sewage disposal system on
permit.

- Contact the local Division
to schedule a final inspectio
- All electric components (c
subsurface sewage disposal
approved by the appropri
requesting a final inspectio
inspection must be availabl

