

Permit Drawing

Michael and Rebecca Montgomery
1671 Cornerstone Road
Independence, VA 24348
Tax Map: 73-3-15/16
HDID: 22-138-052

Class III Well
Drinking Water Well
Minimum 20' casing
Minimum 20' grout

Note: Drawing not to scale.
Z is corner of shed
4 marks windows in
existing shed.

Y is the corner of
middle window.

Well must be a min
of 40' from center
of road.

