



Public Health
Prevent. Promote. Protect.

FINAL/AS-BUILT – Subsurface Sewage Disposal

EASTERN IDAHO PUBLIC HEALTH

1250 HOLLIPARK DRIVE
IDAHO FALLS ID 83401
(208) 523-5382
(208) 528-0857

Permit #: 3021029
Date Rcvd: Oct 08, 2021
Parcel #: RP001420000050

Idaho Public Health Districts

Applicant's Name:	Michael Ivor Fossi		
Owners Name:	Michael Ivor Fossi		
Property Address:	56 Country Living Lane, Salmon ID 83467		
Legal Description:	Township: 21N	Range: 22E	Section: 11
Subdivision: Country Living	Lot: 5	Block:	Size (acres): 7.5

As-Built (not to scale)

System Type:	Gravel (Yards):
Basic, Extra Drainrock	60/River City Red-E-Mix
System Mfg: NA	Sand (Yards): NA
Septic/Trash Tank (Gal):	Installation Depth (Inches):
1000	48
Septic/Trash Tank Mfr:	Rock Under Pipe (Inches):
Dahle	18
Depth to Tank Lid (Inches):	Date System Installed:
12	10/06/2021
Standpipe/ Riser (Inches):	Riser Longitude:
12	NA
Pump Tank (gallons):	Riser Latitude:
NA	NA
Pump Tank Mfg:	Well Installed?
NA	Yes
Drainfield Width (Ft):	Distance to Tank (Ft):
6	>50
Drainfield Length (Ft):	Distance to Drainfield (Ft):
112	>100
Drainfield Area Installed (Sq Ft):	Valve: No
672	
Effective Area (Sq Ft):	Dist-Box: No
840	Drop-Box: No

All plans, specifications, and conditions contained in the approved permit application are hereby incorporated into and may be enforceable as part of the permit.

Technical Allowance Granted? No

Comments:

Notes/Conditions of Approval

Installer Name:	GREG ROACH GRADING AND EXCAVATION INC	Signature:
Installer Phone:	(208) 993-9257	<i>NA</i>
Installer Number:	I-0300	

Date: Nov 29, 2021

By signing above, I certify that all answers and statements on this Final/As-built are true and complete to the best of my knowledge.
Official Use Only

As-Built provided by EHS

Melinda Fuentes
EHS Final Inspection Signature

02
EHS Code

Nov 29, 2021
Date

Final (As-Built) Drawings for Septic Systems

New Septic System

Not to Scale

Permit No:	3021029	Date: 10/08/2021
Parcel: # RP001420000050		
Owner and Installer's Name/Address:	Michael Ivor Fossi 56 Country Living Lane, Salmon, ID. 83467	
Installer(s):	Greg Roach Grading and Excavation, LLC., 208-993-9257, I-0300	
Inspection By:	<i>Melinda Fuentes-Melo</i> , MBA - #02 Environmental Health Specialist	

NORTH

