

INDIVIDUAL SEWAGE DISPOSAL SYSTEM PERMIT APPLICATION AND INSPECTION REPORT

PERMIT # 061-2548 DATE PERMIT ISSUED 12/30/85DATE SYSTEM INSP. 1/8/86 (1:30)RECEIPT # 1003

PROPERTY OWNER & ADDRESS

Monroe GunterRoute ?Canton, Georgia 30114TELEPHONE Jerry BramlettSEWAGE CONTRACTOR 479-5922

PROPERTY LOCATION

Beaver Lake ^{Force ST} Lot # 713

I hereby apply for a permit to install or construct an individual sewage disposal system and agree that the system will be installed to conform to the requirements of the former Georgia Department of Public Health, Chapter 270-5-25.

I understand that final inspection is required and hereby promise to notify the Gilmer County Health Department upon its completion and before applying final cover at 635-4363 or 635-4366.

I further realize and understand that neither this permit nor the final inspection in any way guarantee the proper operations of the sewage system nor in any way confers any guarantee or warranty of any kind.

Owner or applicant's signature

Date

1. Type water supply:

1. individual 2. community 3. public2. 1 New system 2. Repair 3. Existing

3. Perc rate

4. Type facility 2 Bedrooms5. No of bedrooms or gallons Residence6. Subdivision yes no7. Lot size 1/2 Acres8. Building line 35'9. Septic tank capacity min 75010. As installed 750

11. Dosing tank capacity

12. Distance S. T. from well N/A

13. Min. amount of field line:

Ft. sq. 450 Linear ft. 150

14. Field line as installed

Ft. sq. 450 Linear ft. 15015. Width of trench 36"16. Distance between trenches 10'17. Trench depth, avg. 36"18. Distance from foundation 10'-?

19. Nearest property line

front, rear, side

20. Distance from well N/ASite: Approved; Approved conditionally; RejectedSystem: Approved; Approved conditionally; Rejected

REMARKS: Stay 50' from any creek or stream
Allow for 100% replacement of drain-line
Steep slope

Inspector: [Signature]Inspector: [Signature]

GILMER COUNTY HEALTH DEPARTMENT
P.O. BOX 133
ELLIJAY, GEORGIA 30540

