

For Office Use only

RECEIVED

MAR 14 2003

WATER RESOURCES
STATE ENGINEER
COLO.

0502348 E

1. WELL PERMIT NUMBER 58732-F

2. OWNER NAME(S) S. Steven & Linda A. Chelf
Mailing Address 620 Chilcott
City, St Zip Salida, CO 81201
Phone () _____

3. WELL LOCATION AS DRILLED: SW 1/4 SE 1/4, Sec. 5 Twp. 49 N., Range 8 E.
DISTANCES FROM SEC. LINES:
400 ft. from S Sec. line. and 1800 ft. from E Sec. line. OR
(north or south) (east or west)
SUBDIVISION: Country Meadows Estates LOT C BLOCK 1-R FILING(UNIT)
STREET ADDRESS AT WELL LOCATION:

4. GROUND SURFACE ELEVATION 7000 ft. DRILLING METHOD Air Percussion.
DATE COMPLETED January 31, 2003. TOTAL DEPTH 185 ft. DEPTH COMPLETED 185 ft.

5. GEOLOGIC LOG:

Depth	Description of Material (Type, Size, Color, Water Location)
0-12	Brown Sand
12-100	Brown Clay & Boulders
100-150	Brown Clay
150-185	Gray Sand & Gravel

6. HOLE DIAM. (in.)	From (ft)	To (ft)
9-3/4	0	40
6	40	185

7. PLAIN CASING

OD (in)	Kind	Wall Size	From(ft)	To(ft)
6-5/8	Steel	188	+1	140

PERF. CASING: Screen Slot Size: 1/8"

6-5/8 Steel 188 140 185

8. FILTER PACK:

Material _____
Size _____
Interval _____

9. PACKER PLACEMENT:

Type _____

Depth _____

10. GROUTING RECORD:

Material	Amount	Density	Interval	Placement
<u>Cement</u>	<u>50gal</u>	<u>10bags</u>	<u>5-40</u>	<u>poured & vibrated</u>

REMARKS: Tubex 5.5 ID Drive Shoe

11. DISINFECTION: Type	HTH	Amt. Used	3 oz.
------------------------	-----	-----------	-------

12 WELL TEST DATA: ☐ Check box if Test Data is submitted on Form No. GWS 39 Supplemental Well Test.

TESTING METHOD		<u>Air Lift</u>			
Static Level	<u>80</u>	ft. Date/Time measured	<u>1-31-03 1:00pm</u>	Production Rate	<u>30</u> gpm.
Pumping level	<u>185</u>	ft. Date/Time measured	<u>1-31-03 2:00pm</u>	Test length (hrs.)	<u>1</u>
Remarks					

13. I have read the statements made herein and know the contents thereof, and that they are true to my knowledge. [Pursuant to Section 24-4-104 (13) (a) C.R.S., the making of false statements herein constitutes perjury in the second degree and is punishable as a class 1 misdemeanor.]

CONTRACTOR American Drilling Service **Phone** (719)942-3568 **Lic. No.** 1280
Mailing Address 9934 Hwy. 50 Howard, CO 81233

Name/Title (Please type or print)	Signature	Date
Bradford Dewberry/President		3-12-3