

FORM NO.
GWS-32
10/94

PUMP INSTALLATION AND TEST REPORT
STATE OF COLORADO, OFFICE OF THE STATE ENGINEER

For Office Use only

RECEIVED

MAR 14 2003

WATER RESOURCES
STATE ENGINEER
COLO.

0502348E

1.	WELL PERMIT NUMBER <u>58732-F</u>	
2.	OWNER NAME(S) <u>S. Steven & Linda A. Chelf</u> Mailing Address <u>620 Chilcott</u> City, St. Zip <u>Salida, CO 81201</u> Phone ()	
3.	WELL LOCATION AS DRILLED: <u>SW 1/4 SE 1/4</u> , Sec. <u>S</u> Twp. <u>49</u> <u>N</u> , Range <u>8</u> <u>E</u> DISTANCES FROM SEC. LINES: <u>400</u> ft. from <u>S</u> Sec. line. and <u>1800</u> ft. from <u>E</u> Sec. line. (north or south) (east or west) SUBDIVISION: <u>Country Meadows Estates</u> LOT <u>C</u> BLOCK <u>1-R</u> FILING(UNIT) STREET ADDRESS AT WELL LOCATION:	
4.	PUMP DATA: Type <u>Submersible</u> Installation Completed <u>February 7, 2003</u> Pump Manufacturer <u>Myers</u> Pump Model No. <u>3NFL72-12</u> Design GPM <u>12</u> at RPM <u>3450</u> , HP <u>3/4</u> , Volts <u>230</u> , Full Load Amps <u>7.5</u> Pump Intake Depth <u>175</u> Feet, Drop/Column Pipe Size <u>1</u> Inches, Kind <u>SCH 80</u> ADDITIONAL INFORMATION FOR PUMPS GREATER THAT 50 GPM: TURBINE DRIVER TYPE: ☐ Electric ☐ Engine ☐ Other Design Head _____ feet, Number of Stages _____, Shaft size _____ inches.	
5.	OTHER EQUIPMENT: Airline Installed ☐ Yes ☐ No, Orifice Depth ft. _____ Monitor Tube Installed ☐ Yes ☐ No, Depth ft. _____ Flow Meter Mfg. _____ Meter Serial No. _____ Meter Readout ☐ Gallons, ☐ Thousand Gallons, ☐ Acre feet, ☐ Beginning Reading _____	
6.	TEST DATA: ☐ Check box if Test data is submitted on Supplemental Form. Date <u>2-7-03</u> <u>2-7-03</u> Total Well Depth <u>185</u> Time <u>1:00pm</u> <u>3:00pm</u> Static Level <u>80</u> Rate (GPM) <u>15</u> <u>15</u> Date Measured <u>2-7-03</u> Pumping Lvl. <u>80</u> <u>85</u>	
7.	DISINFECTION: Type <u>HTH</u> Amt. Used <u>3 oz.</u>	
8.	Water Quality analysis available. ☐ Yes ☒ No	
9.	Remarks _____ _____ _____ _____ _____	
10.	I have read the statements made herein and know the contents thereof, and that they are true to my knowledge. [Pursuant to Section 24-4-104 (13)(a) C.R.S., the making of false statements herein constitutes perjury in the second degree and is punishable as a class 1 misdemeanor.]	
CONTRACTOR <u>American Drilling Service</u> Phone (<u>719</u>) <u>942-3568</u> Lic. No. <u>1280</u> Mailing Address <u>9934 Hwy. 50 Howard, CO 81233</u>		
Name/Title (Please type or print) <u>Bradford Dewberry/President</u>		Signature <u>Bradford Dewberry</u> Date <u>3-12-03</u>