FORM NO.
GWS-32
08/2008

PUMP INSTALLATION AND TEST REPORT

STATE OF COLORADO, OFFICE OF THE STATE ENGINEER

1313 Sherman St., Room 818, Denver, CO 80203
Info (303) 866-3587 Main (303) 866-3581
Fax (303) 866-3589 http://www.water.state.co.us

For Office Use Only

RECEIVED
AUG 11 2010
WATER RESOURCES
STATE ENGINEER
COLO.

1. WELL PERMIT NUMBER: 182797-A

2. WELL OWNER INFORMATION

NAME OF OWNER
MIRIAM F JEBE

MAILING ADDRESS
7407 KORTZ TR

CITY	STATE	ZIP CODE
SALIDA	CO	81201

TELEPHONE #
( ) -

3. WELL LOCATION AS DRILLED: NW1/4, NE1/4 Sec. 31, Twp. 50 ☒ N or ☐ S, Range 9 ☒ E or ☐ W

DISTANCES FROM SEC. LINES: _____ ft. from ☐ N or ☐ S section line and _____ ft. from ☐ E or ☐ W section line.

SUBDIVISION: _____ LOT ____, BLOCK ____, FILING (UNIT) ____

Optional GPS Location: GPS Unit must use the following settings: Format must be **UTM**, Units must be **meters**, Datum must be **NAD83**, Unit must be set to **true N**, ☐ Zone 12 or ☒ Zone 13

Easting: 411711
Northing: 4267099

STREET ADDRESS AT WELL LOCATION:

4. PUMP DATA: Type: SUBMERSIBLE Date Installed: 7/2/2010

Pump Manufacturer: PUMPS & MORE Pump Model No. 3PM51-10

Design GPM: 10 at RPM 3450 HP 1/2 Volts 230 Full Load Amps 12

Pump Intake Depth: 86 Feet, Drop/Column Pipe Size 1 Inches, Kind of Drop Pipe SCH 80

ADDITIONAL INFORMATION FOR PUMPS GREATER THAN 50 GPM: Turbine Driver Type: ☐ Electric ☐ Engine ☐ Other _____

Design Head feet Number of Stages Shaft size inches

5. OTHER EQUIPMENT:

Airline Installed ☐ Yes ☒ No, Orifice Depth ft. _____ Monitor Tube Installed ☐ Yes ☐ No, Depth ft. _____

Flow Meter Mfg. _____ Meter Serial No. _____

Meter Readout: ☐ Gallons, ☐ Thousand Gallons, ☐ Acre feet Beginning Reading

6. TEST DATA: ☐ check box if Test Data is submitted on Supplemental Form.

	Date:	7-2-10	7-2-10		
Total Well Depth: 100 ft.	Time:	9 AM	11 AM		
Static Level: 45 ft.	Rate (gpm):	14	14		
Date Measured: 7-2-10	Pumping Level (ft):	45	59		

7. DISINFECTION: Type HTH Amt. Used 2 OZ

8. Water Quality analysis available: ☐ Yes ☒ No If yes, please submit with this report.

9. Remarks: _____

10. I have read the statements made herein and know the contents thereof, and they are true to my knowledge. This document is signed and certified in accordance with Rule 17.4 of the Water Well Construction Rules, 2 CCR 402-2. [The filing of a document that contains false statements is a violation of section 37-91-108(1)(e), C.R.S., and is punishable by fines up to $5000 and/or revocation of the contracting license.]

Company Name:	Phone:	License Number:
AMERICAN DRILLING SERVICE	(719)942-3568	1280

Mailing Address:
9934 HWY 50 HOWARD, CO 81233

Signature:	Print Name and Title	Date
Bradford Dewberry	BRADFORD DEWBERRY - PRESIDENT	8/8/2010